ALS Canada Ltd.



CERTIFICATE OF ANALYSIS (GUIDELINE EVALUATION)

: VA22C6740 **Work Order** Page : 1 of 3

Client Laboratory : Vancouver - Environmental : Vancouver School Board

: Stephen Thomas Contact **Account Manager** : Tasnia Tarannum Address

: 1549 Clark Drive Address : 8081 Lougheed Highway Vancouver BC Canada V5L 3L4

Burnaby, British Columbia Canada V5A 1W9

: ----Telephone : +1 604 253 4188

Project : General Brock Elementary **Date Samples Received** : 03-Nov-2022 14:55 **Date Analysis Commenced** : 08-Nov-2022

: 15-Nov-2022 09:32 C-O-C number : 20-1016773 Issue Date

: R.Lemay Site : ----Quote number No. of samples received : 6 No. of samples analysed : 6

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results
- Guideline Comparison

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

Signatories

Telephone

PO

Sampler

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories Laboratory Department Position

Kevin Duarte Supervisor - Metals ICP Instrumentation Metals, Burnaby, British Columbia Page : 2 of 3 Work Order : VA22C6740

Client : Vancouver School Board
Project : General Brock Elementary



No Breaches Found

General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information. Guidelines are not adjusted for the hardness, pH or temperature of the sample (the most conservative values are used). Measurement uncertainty is not applied to test results prior to comparison with specified criteria values.

Key: LOR: Limit of Reporting (detection limit).

Unit	Description
mg/L	milligrams per litre

>: greater than.

Red shading is applied where the result is greater than the Guideline Upper Limit or the result is lower than the Guideline Lower Limit.

For drinking water samples, Red shading is applied where the result for E.coli, fecal or total coliforms is greater than or equal to the Guideline Upper Limit.

<: less than.

 Page
 :
 3 of 3

 Work Order
 :
 VA22C6740

Client : Vancouver School Board
Project : General Brock Elementary



Analytical Results Evaluation

Matrix:	Clien	t sample ID		 	 	
	Samplin	ng date/time		 	 	
		Sub-Matrix			 	
Analyte	CAS Number	Unit		 	 	
		-				
Please refer to the General Comments	section for an explanation of any qu	ualifiers dete	cted.			
lead, total		439-92-1	mg/L			



QUALITY CONTROL INTERPRETIVE REPORT

Work Order : **VA22C6740** Page : 1 of 5

Client : Vancouver School Board Laboratory : Vancouver - Environmental

Contact : Stephen Thomas Account Manager : Tasnia Tarannum

Address :1549 Clark Drive Address :8081 Lougheed Highway

Burnaby, British Columbia Canada V5A 1W9

Telephone :--- Telephone :+1 604 253 4188

Project : General Brock Elementary Date Samples Received : 03-Nov-2022 14:55
PO :---- Issue Date : 15-Nov-2022 09:32

C-O-C number : 20-1016773
Sampler : R.Lemay

Site :---Quote number :---No. of samples received :6
No. of samples analysed :6

This report is automatically generated by the ALS LIMS (Laboratory Information Management System) through evaluation of Quality Control (QC) results and other QA parameters associated with this submission, and is intended to facilitate rapid data validation by auditors or reviewers. The report highlights any exceptions and outliers to ALS Data Quality Objectives, provides holding time details and exceptions, summarizes QC sample frequencies, and lists applicable methodology references and summaries.

Key

Anonymous: Refers to samples which are not part of this work order, but which formed part of the QC process lot.

CAS Number: Chemical Abstracts Service number is a unique identifier assigned to discrete substances.

Vancouver BC Canada V5L 3L4

DQO: Data Quality Objective.

LOR: Limit of Reporting (detection limit).

RPD: Relative Percent Difference.

Workorder Comments

Holding times are displayed as "---" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Summary of Outliers

Outliers : Quality Control Samples

- No Method Blank value outliers occur.
- No Duplicate outliers occur.
- No Laboratory Control Sample (LCS) outliers occur
- No Matrix Spike outliers occur.
- No Test sample Surrogate recovery outliers exist.

Outliers: Reference Material (RM) Samples

No Reference Material (RM) Sample outliers occur.

Outliers: Analysis Holding Time Compliance (Breaches) ■ No Analysis Holding Time Outliers exist.

Outliers: Frequency of Quality Control Samples • No Quality Control Sample Frequency Outliers occur.

Page : 3 of 5 Work Order : VA22C6740

Client : Vancouver School Board
Project : General Brock Elementary



Analysis Holding Time Compliance

This report summarizes extraction / preparation and analysis times and compares each with ALS recommended holding times, which are selected to meet known provincial and/or federal requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by organizations such as CCME, US EPA, APHA Standard Methods, ASTM, or Environment Canada (where available). Dates and holding times reported below represent the first dates of extraction or analysis. If subsequent tests or dilutions exceeded holding times, qualifiers are added (refer to COA).

If samples are identified below as having been analyzed or extracted outside of recommended holding times, measurement uncertainties may be increased, and this should be taken into consideration when interpreting results.

Where actual sampling date is not provided on the chain of custody, the date of receipt with time at 00:00 is used for calculation purposes.

Where only the sample date without time is provided on the chain of custody, the sampling date at 00:00 is used for calculation purposes.

Matrix: Water Evaluation: × = Holding time exceedance: ✓ = Within Holding Time

vatrix: water						/aiuation. * =	Holding time exceedance; • = within Holding						
Analyte Group	Method	Sampling Date	Ext	traction / Pr	reparation			Analy	sis				
Container / Client Sample ID(s)			Preparation	Holdin	g Times	Eval	Analysis Date	Holdin	g Times	Eval			
			Date	Rec	Actual			Rec	Actual				
Total Metals : Total metals in Water by CRC ICPMS													
HDPE - total (lab preserved)													
Corr. 101 Rm. C109 B.F	E420	03-Nov-2022	08-Nov-2022				10-Nov-2022	180	7 days	✓			
								days					
Total Metals : Total metals in Water by CRC ICPMS													
HDPE - total (lab preserved)													
Corr. 205 Rm. 205A D.F	E420	03-Nov-2022	08-Nov-2022				10-Nov-2022	180	7 days	✓			
								days					
Total Metals : Total metals in Water by CRC ICPMS													
HDPE - total (lab preserved)													
Corr.101 Rm. B111 D.F	E420	03-Nov-2022	08-Nov-2022				10-Nov-2022	180	7 days	✓			
								days					
Total Metals : Total metals in Water by CRC ICPMS													
HDPE - total (lab preserved)													
Play Area 001 D.F	E420	03-Nov-2022	08-Nov-2022				10-Nov-2022	180	7 days	✓			
								days					
Total Metals : Total metals in Water by CRC ICPMS													
HDPE - total (lab preserved)													
Play Area 005 D.F	E420	03-Nov-2022	08-Nov-2022				10-Nov-2022	180	7 days	✓			
								days					
Total Metals : Total metals in Water by CRC ICPMS													
HDPE - total (lab preserved)													
Rm. 130 Girls Change Rm. D.F	E420	03-Nov-2022	08-Nov-2022				10-Nov-2022	180	7 days	✓			
								days					

Legend & Qualifier Definitions

Rec. HT: ALS recommended hold time (see units).

Page : 4 of 5 Work Order : VA22C6740

Client : Vancouver School Board
Project : General Brock Elementary



Quality Control Parameter Frequency Compliance

The following report summarizes the frequency of laboratory QC samples analyzed within the analytical batches (QC lots) in which the submitted samples were processed. The actual frequency should be greater than or equal to the expected frequency.

Matrix: Water Evaluation: × = QC frequency outside specification; ✓ = QC frequency within specific													
Quality Control Sample Type			Co	ount	Frequency (%)								
Analytical Methods	Method	QC Lot #	QC	Regular	Actual	Expected	Evaluation						
Laboratory Duplicates (DUP)													
Total metals in Water by CRC ICPMS	E420	733907	1	14	7.1	5.0	✓						
Laboratory Control Samples (LCS)													
Total metals in Water by CRC ICPMS	E420	733907	1	14	7.1	5.0	✓						
Method Blanks (MB)													
Total metals in Water by CRC ICPMS	E420	733907	1	14	7.1	5.0	✓						
Matrix Spikes (MS)													
Total metals in Water by CRC ICPMS	E420	733907	1	14	7.1	5.0	✓						

Page : 5 of 5 Work Order : VA22C6740

Client : Vancouver School Board
Project : General Brock Elementary



Methodology References and Summaries

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Reference methods may incorporate modifications to improve performance (indicated by "mod").

Analytical Methods	Method / Lab	Matrix	Method Reference	Method Descriptions
Total metals in Water by CRC ICPMS	E420	Water	EPA 200.2/6020B	Water samples are digested with nitric and hydrochloric acids, and analyzed by
			(mod)	Collision/Reaction Cell ICPMS.
	Vancouver -			
	Environmental			Method Limitation (re: Sulfur): Sulfide and volatile sulfur species may not be recovered
				by this method.

ALS Canada Ltd.



QUALITY CONTROL REPORT

Work Order :VA22C6740

Client : Vancouver School Board

: Stephen Thomas Address : 1549 Clark Drive

Vancouver BC Canada V5L 3L4

Telephone

Contact

Project : General Brock Elementary

PO

C-O-C number :20-1016773 Sampler :R.Lemay

Site Quote number No. of samples received : 6 No. of samples analysed : 6 Page : 1 of 3

Laboratory : Vancouver - Environmental

Account Manager : Tasnia Tarannum

Address :8081 Lougheed Highway

Burnaby, British Columbia Canada V5A 1W9

Telephone :+1 604 253 4188

Date Samples Received :03-Nov-2022 14:55

Date Analysis Commenced : 08-Nov-2022

Issue Date : 15-Nov-2022 09:32

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Quality Control Report contains the following information:

Laboratory Duplicate (DUP) Report; Relative Percent Difference (RPD) and Data Quality Objectives

- Matrix Spike (MS) Report; Recovery and Data Quality Objectives
- Method Blank (MB) Report; Recovery and Data Quality Objectives
- Laboratory Control Sample (LCS) Report; Recovery and Data Quality Objectives

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories **Position** Laboratory Department

Kevin Duarte Supervisor - Metals ICP Instrumentation Vancouver Metals, Burnaby, British Columbia Page : 2 of 3 Work Order : VA22C6740

Client : Vancouver School Board
Project : General Brock Elementary



General Comments

The ALS Quality Control (QC) report is optionally provided to ALS clients upon request. ALS test methods include comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against predetermined Data Quality Objectives (DQOs) to provide confidence in the accuracy of associated test results. This report contains detailed results for all QC results applicable to this sample submission. Please refer to the ALS Quality Control Interpretation report (QCI) for applicable method references and methodology summaries.

Key:

Anonymous = Refers to samples which are not part of this work order, but which formed part of the QC process lot.

CAS Number = Chemical Abstracts Service number is a unique identifier assigned to discrete substances.

DQO = Data Quality Objective.

LOR = Limit of Reporting (detection limit).

RPD = Relative Percent Difference

= Indicates a QC result that did not meet the ALS DQO.

Workorder Comments

Holding times are displayed as "---" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Laboratory Duplicate (DUP) Report

A Laboratory Duplicate (DUP) is a randomly selected intralaboratory replicate sample. Laboratory Duplicates provide information regarding method precision and sample heterogeneity. ALS DQOs for Laboratory Duplicates are expressed as test-specific limits for Relative Percent Difference (RPD), or as an absolute difference limit of 2 times the LOR for low concentration duplicates within ~ 4-10 times the LOR (cut-off is test-specific).

Sub-Matrix: Water			Laboratory Duplicate (DUP) Report											
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	LOR	Unit	Original Result	Duplicate Result	RPD(%) or Difference	Duplicate Limits	Qualifier			
Total Metals (QC Lo	t: 733907)													
VA22C6675-001	Anonymous	lead, total	7439-92-1	E420	0.000050	mg/L	<0.000050	<0.000050	0	Diff <2x LOR				

Method Blank (MB) Report

A Method Blank is an analyte-free matrix that undergoes sample processing identical to that carried out for test samples. Method Blank results are used to monitor and control for potential contamination from the laboratory environment and reagents. For most tests, the DQO for Method Blanks is for the result to be < LOR.

Sub-Matrix: Water

Analyte	CAS Number	Method	LOR	Unit	Result	Qualifier
Total Metals (QCLot: 733907)						
lead, total	7439-92-1 E	E420	0.00005	mg/L	<0.000050	

Page : 3 of 3 Work Order : VA22C6740

Client : Vancouver School Board
Project : General Brock Elementary



Laboratory Control Sample (LCS) Report

A Laboratory Control Sample (LCS) is an analyte-free matrix that has been fortified (spiked) with test analytes at known concentration and processed in an identical manner to test samples. LCS results are expressed as percent recovery, and are used to monitor and control test method accuracy and precision, independent of test sample matrix.

Sub-Matrix: Water		Laboratory Control Sample (LCS) Report									
		Spike	Recovery (%)	Recovery	Limits (%)						
Analyte	CAS Number	Method	LOR	Unit	Concentration	LCS	Low	High	Qualifier		
Total Metals (QCLot: 733907)											
lead, total	7439-92-1	E420	0.00005	mg/L	0.5 mg/L	102	80.0	120			

Matrix Spike (MS) Report

A Matrix Spike (MS) is a randomly selected intra-laboratory replicate sample that has been fortified (spiked) with test analytes at known concentration, and processed in an identical manner to test samples. Matrix Spikes provide information regarding analyte recovery and potential matrix effects. MS DQO exceedances due to sample matrix may sometimes be unavoidable; in such cases, test results for the associated sample (or similar samples) may be subject to bias. ND – Recovery not determined, background level >= 1x spike level.

Sub-Matrix: Water				Matrix Spike (MS) Report												
					Spi	ike	Recovery (%)	Recovery	Limits (%)							
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	Concentration	Target	MS	Low	High	Qualifier						
Total Metals (QC	Lot: 733907)															
VA22C6740-001	Rm. 130 Girls Change Rm. D.F	lead, total	7439-92-1	E420	0.0196 mg/L	0.02 mg/L	98.2	70.0	130							



www.alsglobal.com

Canada Toll Free: 1 800 668 9878

Released by: SHIPMEN KELEASE (client use) Time: Released by:		or Human consumption/ user	No	Are samples taken from a Regulated DW System?	minum a states (nest) complete (energy sees)	Water (DW) Samples (client use)				Play	Play area 005 D.F.	651, 101 K	1. Corr. 101 Rm. c/09 B.F.	Corr. 2054 205 Km. 2054	Km. BO Gills Change	(ALS use only). (This description will appear on the report)	rk Order # (ALS use only): 6740		/	Job#: General Brock Elementary Major	ALS Account # / Quote #	Project Information		YES NO	Invoice To Same as Report To 🔀 YES 🗌 NO		ovince: Vancouver B.C.	Street 1549 Chick Dr. Ema	s below will appear on the final report	604-313-5637	Contact: Stephen Thomas	
Received by Date: Date:	THE PROPERTY OF COUNTY OF COUNTY		preservatives added	Sut	(Excel COC anly)	ecting from drop-down below				03-11-22 8:17 water	03-11-22 8:15 water	03-11-22 8:05 water	03-11-22 7:50 water	03-11-22 7:47 water	03-11-22 7:41 water	(dd-mmm-yy) (hh:mm) Sample Type 2	10 N Samp	s'	Requisitioner:	MajorMinor Code: Routing Code:	AFE/Cost Center: PO#	Oil and Gas Required Fields (client use)		Select Invoice Distribution: 🄀 BMAIL 🗌 MAIL 🗍 FAX	Invoice Recipients	iduana @usb.bc.	aile carrell @ usb. bc.ca		Select Distribution: 🔀 EMAIL 🗆 MAIL 🗆 FAX	provide details below if box checked	orts with COA	יייי איייייייייייייייייייייייייייייייי
Time: Received by: Date: 102 1/2 3 Time: Time: 72 1/2 3	THE PROPERTY OF THE PROPERTY O		Cooler Custody Seals Intact	d on Sample Receipt N	Cooling Method: I NONE INTIATED ROZEN INTIATED	SAMPLE RECEIPT DETAILS (ALS use only) ************************************		Telephone: +1 604 253 4100				VAZZOO	Work Order Tensor 79740	Vancouver	Environmental Division	SA	MPLE	d ES (DN .	НО			Indicate Filtered (F), Preserved (P) or Filtered and Preserved (F/P) below	Analysis Request	For all tests with rush TATs requested, please contact your AM to confirm availability.	hhann	may apply to rush requests on weekends, statutory holidays and non-routine tests	Same day [EZ] if received by 10am M-S - 200% rush surcharge. Additional fees			a day [P4] if received by 3pm M-F - 20% rush surcharge minimum	

WHITE - LABORATORY COPY YELLOW - CLIENT COPY
Failure to complete all portions of this form may delay analysis. Please fill in this form LEGIBLY. By the use of this form the user acknowledges and agrees with the Terms and Conditions as specified on the back page of the white - report copy.

1. If any water samples are taken from a Regulated Drinking Water (DW) System, please submit using an Authorized DW COC form.

Results Summary VA22C6740

Project General Brock Elementary

Report To Stephen Thomas, Vancouver School Board

 Date Received
 03-Nov-2022 14:55

 Issue Date
 15-Nov-2022 09:33

Amendment

Client Sample ID			Rm. 130 Girls Change Rm. D.F	Corr. 205 Rm. 205A D.F	Corr. 101 Rm. C109 B.F	Corr.101 Rm. B111 D.F	Play Area 005 D.F	Play Area 001 D.F
Date Sampled			03-Nov-2022	03-Nov-2022	03-Nov-2022	03-Nov-2022	03-Nov-2022	03-Nov-2022
Time Sampled			07:41	07:47	07:50	08:05	08:15	08:17
ALS Sample ID			VA22C6740-001	VA22C6740-002	VA22C6740-003	VA22C6740-004	VA22C6740-005	VA22C6740-006
Analyte	Lowest Detection Limit	Units	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water
Total Metals (Matrix: Water)								
lead, total	0.000050	mg/L	0.0145	0.000306	0.000184	0.000979	0.00145	0.0377