



VANCOUVER SCHOOL BOARD
ATTN: Facilities
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4

Date Received: 29-SEP-16
Report Date: 03-OCT-16 15:58 (MT)
Version: FINAL REV. 3

Client Phone: --

Certificate of Analysis

Lab Work Order #: L1836615
Project P.O. #: NOT SUBMITTED
Job Reference:
C of C Numbers: 15-593782
Legal Site Desc:

Comments: Omitting result for sample 1: 1CARN DF117 RETEST

Heather McKenzie
Account Manager

[This report shall not be reproduced except in full without the written authority of the Laboratory.]

ADDRESS: 8081 Lougheed Hwy, Suite 100, Burnaby, BC V5A 1W9 Canada | Phone: +1 604 253 4188 | Fax: +1 604 253 6700
ALS CANADA LTD Part of the ALS Group A Campbell Brothers Limited Company

ALS ENVIRONMENTAL ANALYTICAL REPORT

Sample ID Description Sampled Date Sampled Time Client ID	L1836615-2 Water 29-SEP-16 14:20 2 CARN DF117 RETEST				
Grouping	Analyte				
WATER					
Total Metals	Lead (Pb)-Total (mg/L)	0.00731			



VANCOUVER SCHOOL BOARD
ATTN: Facilities
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4

Date Received: 24-JUN-16
Report Date: 04-JUL-16 15:45 (MT)
Version: FINAL

Client Phone: --

Certificate of Analysis

Lab Work Order #: L1788976
Project P.O. #: 0000125902
Job Reference:
C of C Numbers: 15-567149, 15-567190, 15-567191
Legal Site Desc:

Dean Watt, B.Sc.
Account Manager

[This report shall not be reproduced except in full without the written authority of the Laboratory.]

ADDRESS: 8081 Lougheed Hwy, Suite 100, Burnaby, BC V5A 1W9 Canada | Phone: +1 604 253 4188 | Fax: +1 604 253 6700
ALS CANADA LTD Part of the ALS Group A Campbell Brothers Limited Company

ALS ENVIRONMENTAL ANALYTICAL REPORT

		Sample ID	L1788976-24	L1788976-25	L1788976-26		
		Description	Water	Water	Water		
		Sampled Date	24-JUN-16	24-JUN-16	24-JUN-16		
		Sampled Time	10:10	10:05	10:00		
		Client ID	CARNARVON 117-DF	CARNARVON 163-DF	CARNARVON 157-DF		
Grouping	Analyte						
WATER							
Total Metals	Lead (Pb)-Total (mg/L)		0.0427	0.00344	0.00176		