



Date: 17-OCT-19

PO No.: 1517879

WO No.: L2363042

LSD:

Project Ref: DAVID LIVINGSTONE ELEMENTARY

Sample ID: RM. 022 DF


Sampled By: Robin Lemay

Date Collected: 09-OCT-19

Lab Sample ID: L2363042-1

Matrix: Water

VANCOUVER SCHOOL BOARD  
Maintenance and Construction  
1549 Clark Drive  
Vancouver BC V5L 3L4  
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
<b>Total Metals</b> Lead (Pb)-Total	0.000584		mg/L	0.005		12-OCT-19
<p><b>CDWQG = Health Canada Guideline Limits updated JUNE 2019</b></p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L &lt; or N.D. = less than detection limit.            * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality            - A blank entry designates no known limit.            - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by             Edward Ngai            Account Manager</p>						



Date: 17-OCT-19

PO No.: 1517879

WO No.: L2363042

LSD:

Project Ref: DAVID LIVINGSTONE ELEMENTARY

Sample ID: RM. 016 DF


Sampled By: Robin Lemay

Date Collected: 09-OCT-19

Lab Sample ID: L2363042-2

Matrix: Water

VANCOUVER SCHOOL BOARD  
Maintenance and Construction  
1549 Clark Drive  
Vancouver BC V5L 3L4  
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
<b>Total Metals</b> Lead (Pb)-Total	0.000439		mg/L	0.005		12-OCT-19
<p><b>CDWQG = Health Canada Guideline Limits updated JUNE 2019</b></p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L &lt; or N.D. = less than detection limit.            * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality            - A blank entry designates no known limit.            - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by             Edward Ngai            Account Manager</p>						



Date: 17-OCT-19

PO No.: 1517879

WO No.: L2363042

LSD:

Project Ref: DAVID LIVINGSTONE ELEMENTARY

Sample ID: KINDER 101 DF


Sampled By: Robin Lemay

Date Collected: 09-OCT-19

Lab Sample ID: L2363042-3

Matrix: Water

VANCOUVER SCHOOL BOARD  
Maintenance and Construction  
1549 Clark Drive  
Vancouver BC V5L 3L4  
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
<b>Total Metals</b> Lead (Pb)-Total	0.000733		mg/L	0.005		12-OCT-19
<p><b>CDWQG = Health Canada Guideline Limits updated JUNE 2019</b></p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L &lt; or N.D. = less than detection limit.            * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality            - A blank entry designates no known limit.            - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by             Edward Ngai            Account Manager</p>						



Date: 17-OCT-19

PO No.: 1517879

WO No.: L2363042

LSD:

Project Ref: DAVID LIVINGSTONE ELEMENTARY

Sample ID: RM. 209A DF


Sampled By: Robin Lemay

Date Collected: 09-OCT-19

Lab Sample ID: L2363042-4

Matrix: Water

VANCOUVER SCHOOL BOARD  
Maintenance and Construction  
1549 Clark Drive  
Vancouver BC V5L 3L4  
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
<b>Total Metals</b> Lead (Pb)-Total	0.000134		mg/L	0.005		12-OCT-19
<p><b>CDWQG = Health Canada Guideline Limits updated JUNE 2019</b></p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L &lt; or N.D. = less than detection limit.            * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality            - A blank entry designates no known limit.            - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by             Edward Ngai            Account Manager</p>						



Date: 17-OCT-19

PO No.: 1517879

WO No.: L2363042

LSD:

Project Ref: DAVID LIVINGSTONE ELEMENTARY

Sample ID: RM. 103 DF

Sampled By: Robin Lemay


Date Collected: 09-OCT-19

Lab Sample ID: L2363042-5

Matrix: Water

**VANCOUVER SCHOOL BOARD**  
**Maintenance and Construction**  
 1549 Clark Drive  
 Vancouver BC V5L 3L4  
 ATTN: Stephen Thomas

PAGE 5 of 10

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
<b>Total Metals</b> Lead (Pb)-Total	0.000330		mg/L	0.005		12-OCT-19
<p><b>CDWQG = Health Canada Guideline Limits updated JUNE 2019</b></p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L &lt; or N.D. = less than detection limit.            * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality            - A blank entry designates no known limit.            - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by             Edward Ngai            Account Manager</p>						

ADDRESS: 8081 Lougheed Hwy, Suite 100, Burnaby, BC V5A 1W9 Canada | Phone: +1 604 253 4188 | Fax: +1 604 253 6700

ALS CANADA LTD Part of the ALS Group A Campbell Brothers Limited Company



Date: 17-OCT-19

PO No.: 1517879

WO No.: L2363042

LSD:

Project Ref: DAVID LIVINGSTONE ELEMENTARY

Sample ID: RM. 112B DF


Sampled By: Robin Lemay

Date Collected: 09-OCT-19

Lab Sample ID: L2363042-6

Matrix: Water

VANCOUVER SCHOOL BOARD  
Maintenance and Construction  
1549 Clark Drive  
Vancouver BC V5L 3L4  
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
<b>Total Metals</b> Lead (Pb)-Total	0.000111		mg/L	0.005		12-OCT-19
<p><b>CDWQG = Health Canada Guideline Limits updated JUNE 2019</b></p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L &lt; or N.D. = less than detection limit.            * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality            - A blank entry designates no known limit.            - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by             Edward Ngai            Account Manager</p>						



Date: 17-OCT-19

PO No.: 1517879

WO No.: L2363042

LSD:

Project Ref: DAVID LIVINGSTONE ELEMENTARY

Sample ID: RM. 001 DF


Sampled By: Robin Lemay

Date Collected: 09-OCT-19

Lab Sample ID: L2363042-7

Matrix: Water

**VANCOUVER SCHOOL BOARD**  
**Maintenance and Construction**  
 1549 Clark Drive  
 Vancouver BC V5L 3L4  
 ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
<b>Total Metals</b> Lead (Pb)-Total	0.000061		mg/L	0.005		12-OCT-19
<p><b>CDWQG = Health Canada Guideline Limits updated JUNE 2019</b></p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L &lt; or N.D. = less than detection limit.            * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality            - A blank entry designates no known limit.            - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by             Edward Ngai            Account Manager</p>						



Date: 17-OCT-19

PO No.: 1517879

WO No.: L2363042

LSD:

Project Ref: DAVID LIVINGSTONE ELEMENTARY

Sample ID: CORR 100 RM. 026 SSDF

Sampled By: Robin Lemay


Date Collected: 09-OCT-19

Lab Sample ID: L2363042-8

Matrix: Water

**VANCOUVER SCHOOL BOARD**  
**Maintenance and Construction**  
 1549 Clark Drive  
 Vancouver BC V5L 3L4  
 ATTN: Stephen Thomas

PAGE 8 of 10

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
<b>Total Metals</b> Lead (Pb)-Total	0.000249		mg/L	0.005		12-OCT-19
<p><b>CDWQG = Health Canada Guideline Limits updated JUNE 2019</b></p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L &lt; or N.D. = less than detection limit.            * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality            - A blank entry designates no known limit.            - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by             Edward Ngai            Account Manager</p>						

ADDRESS: 8081 Lougheed Hwy, Suite 100, Burnaby, BC V5A 1W9 Canada | Phone: +1 604 253 4188 | Fax: +1 604 253 6700

ALS CANADA LTD Part of the ALS Group A Campbell Brothers Limited Company





Date: 17-OCT-19

PO No.: 1517879

WO No.: L2363042

LSD:

Project Ref: DAVID LIVINGSTONE ELEMENTARY

Sample ID: CORR 011 RM. 012 DF


Sampled By: Robin Lemay

Date Collected: 09-OCT-19

Lab Sample ID: L2363042-9

Matrix: Water

VANCOUVER SCHOOL BOARD  
Maintenance and Construction  
1549 Clark Drive  
Vancouver BC V5L 3L4  
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
<b>Total Metals</b> Lead (Pb)-Total	0.000163		mg/L	0.005		12-OCT-19
<p><b>CDWQG = Health Canada Guideline Limits updated JUNE 2019</b></p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L &lt; or N.D. = less than detection limit.            * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality            - A blank entry designates no known limit.            - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by             Edward Ngai            Account Manager</p>						

## Guidelines & Objectives

### Health Canada MAC Health Related Criteria Limits

Nitrate/Nitrite-N*	Criteria limit is 10 mg/L (1.0 mg/L if present as all Nitrite-N). High concentrations may contribute to blue baby syndrome in infants.
Lead*	A cumulative body poison, uncommon in naturally occurring hard waters.
Fluoride*	Present in fluoridated water supplies at 0.8 mg/L to reduce dental caries. Elevated levels causes fluorosis (mottling of teeth).
Total Coliforms*	Criteria is 0 CFU/100mL. Adverse health effects.
E. Coli*	Criteria is 0 CFU/100 mL. Certain E. Coli bacteria can be life threatening.
Manganese*	Criteria limit is 0.12 mg/L. Possible neurological effects in infants.

\*Health Canada Canadian Drinking Water Quality Guidelines (MAC limit)

### Aesthetic Objective Concentration Levels

Alkalinity	Acid neutralizing capacity. Usually a measure of carbonate and bicarbonates and calculated and reported as calcium carbonate.
Balance	Quality control parameter ratiating cations to anions
Bicarbonate	See Alkalinity. Report as the anion HCO <sub>3</sub> -1
Carbonate	See Alkalinity. Reported at the anion CO <sub>3</sub> -2
Calcium	See Hardness. Common major cation of water chemistry.
Chloride	Common major anion of water chemistry.
Conductance	Physical test measuring water salinity (dissolved ions or solids)
Hardness	Classical measure or capacity of water to precipitate soap (chiefly calcium and magnesium ions). Causes scaling tendency in water if carbonates/bicarbonates are present (if >200 mg/L). For drinking water purposes waters with results <200 mg/L are considered acceptable, results >200 mg/L are considered poor but can be tolerated. Results >500 mg/L are unacceptable.
Hydroxide	See alkalinity
Magnesium	See hardness. Common major cation of water chemistry. Elevated levels (>125 mg/L) may exert a cathartic or diuretic action.
pH	Measure of water acidity/alkalinity. Normal range is 7.0-8.5.
Potassium	Common major cation of water chemistry.
Sodium	Common major cation of water chemistry. Measure of salinity (saltiness).
Sulphate	Common major anion of water chemistry. Elevated levels may exert a cathartic or diuretic action.
Total Dissolved Solids	A measure of water salinity.
Iron	Causes staining to laundry and porcelain and astringent taste. Oxidizes to red-brown precipitate on exposure to air.
Heterotrophic	
Plate Count	Criteria is 500 cfu/mL Measure of heterotrophic bacteria present.

### GLOSSARY OF REPORT TERMS

*Surrogates are compounds that are similar in behaviour to target analyte(s), but that do not normally occur in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery. In reports that display the D.L. column, laboratory objectives for surrogates are listed there.*

*mg/kg - milligrams per kilogram based on dry weight of sample*

*mg/kg wwt - milligrams per kilogram based on wet weight of sample*

*mg/kg lwt - milligrams per kilogram based on lipid-adjusted weight*

*mg/L - unit of concentration based on volume, parts per million.*

*< - Less than.*

*D.L. - The reporting limit.*

*N/A - Result not available. Refer to qualifier code and definition for explanation.*

*Test results reported relate only to the samples as received by the laboratory.*

*UNLESS OTHERWISE STATED, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.*

*Analytical results in unsigned test reports with the DRAFT watermark are subject to change, pending final QC review.*

