



VANCOUVER SCHOOL BOARD
ATTN: FACILITIES
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4

Date Received: 01-JUN-16
Report Date: 08-JUN-16 17:55 (MT)
Version: FINAL

Client Phone: --

Certificate of Analysis

Lab Work Order #: L1777109
Project P.O. #: 0000125902
Job Reference:
C of C Numbers: 10-379658, 14-498513
Legal Site Desc:

Comments: Reporting results for each school separately.

Dean Watt, B.Sc.
Account Manager

[This report shall not be reproduced except in full without the written authority of the Laboratory.]

ADDRESS: 8081 Lougheed Hwy, Suite 100, Burnaby, BC V5A 1W9 Canada | Phone: +1 604 253 4188 | Fax: +1 604 253 6700
ALS CANADA LTD Part of the ALS Group A Campbell Brothers Limited Company

ALS ENVIRONMENTAL ANALYTICAL REPORT

		Sample ID	L1777109-1	L1777109-3	L1777109-9	L1777109-13
		Description	WATER	WATER	WATER	WATER
		Sampled Date	01-JUN-16	01-JUN-16	01-JUN-16	01-JUN-16
		Sampled Time	08:15	08:20	08:25	08:10
		Client ID	THOMPSON 232-SINK	THOMPSON 214-DF	THOMPSON 254-DF	THOMPSON 320-DF
Grouping	Analyte					
WATER						
Total Metals	Lead (Pb)-Total (mg/L)	0.000964	0.00202	0.00757	0.00210	