



## CERTIFICATE OF ANALYSIS (GUIDELINE EVALUATION)

**Work Order** : **VA22A3804**  
**Client** : **Vancouver School Board**  
**Contact** : **Stephen Thomas**  
**Address** : **1549 Clark Drive**  
**Vancouver BC Canada V5L 3L4**  
**Telephone** : **----**  
**Project** : **----**  
**PO** : **----**  
**C-O-C number** : **20-986565**  
**Sampler** : **Robin LeMay**  
**Site** : **----**  
**Quote number** : **----**  
**No. of samples received** : **6**  
**No. of samples analysed** : **6**

**Page** : **1 of 3**  
**Laboratory** : **Vancouver - Environmental**  
**Account Manager** : **Tasnia Tarannum**  
**Address** : **8081 Lougheed Highway**  
**Burnaby, British Columbia Canada V5A 1W9**  
**Telephone** : **+1 604 253 4188**  
**Date Samples Received** : **24-Feb-2022 15:00**  
**Date Analysis Commenced** : **05-Mar-2022**  
**Issue Date** : **10-Mar-2022 16:41**

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results
- Guideline Comparison

**Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).**

### Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Laboratory Department</i>
Angela Ren	Team Leader - Metals	Metals, Burnaby, British Columbia
Kevin Duarte	Supervisor - Metals ICP Instrumentation	Metals, Burnaby, British Columbia



### General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information. Guidelines are not adjusted for the hardness, pH or temperature of the sample (the most conservative values are used). Measurement uncertainty is not applied to test results prior to comparison with specified criteria values.

Key : LOR: Limit of Reporting (detection limit).

Unit	Description
mg/L	milligrams per litre

>: greater than.

<: less than.

Red shading is applied where the result is greater than the Guideline Upper Limit or the result is lower than the Guideline Lower Limit.

For drinking water samples, Red shading is applied where the result for E.coli, fecal or total coliforms is greater than or equal to the Guideline Upper Limit.

### Analytical Results Evaluation

Matrix:	Client sample ID	----	----	----	----	----	----	----
	Sampling date/time	----	----	----	----	----	----	----
	Sub-Matrix	----	----	----	----	----	----	----
Analyte	CAS Number	Unit	----	----	----	----	----	----
		-						

Please refer to the General Comments section for an explanation of any qualifiers detected.



**No Breaches Found**

lead, total	7439-92-1	mg/L								
-------------	-----------	------	--	--	--	--	--	--	--	--

## QUALITY CONTROL INTERPRETIVE REPORT

Work Order	: <b>VA22A3804</b>	Page	: 1 of 5
Client	: <b>Vancouver School Board</b>	Laboratory	: Vancouver - Environmental
Contact	: Stephen Thomas	Account Manager	: Tasnia Tarannum
Address	: 1549 Clark Drive Vancouver BC Canada V5L 3L4	Address	: 8081 Lougheed Highway Burnaby, British Columbia Canada V5A 1W9
Telephone	: ----	Telephone	: +1 604 253 4188
Project	: ----	Date Samples Received	: 24-Feb-2022 15:00
PO	: ----	Issue Date	: 10-Mar-2022 16:41
C-O-C number	: 20-986565		
Sampler	: Robin LeMay		
Site	: ----		
Quote number	: ----		
No. of samples received	: 6		
No. of samples analysed	: 6		

This report is automatically generated by the ALS LIMS (Laboratory Information Management System) through evaluation of Quality Control (QC) results and other QA parameters associated with this submission, and is intended to facilitate rapid data validation by auditors or reviewers. The report highlights any exceptions and outliers to ALS Data Quality Objectives, provides holding time details and exceptions, summarizes QC sample frequencies, and lists applicable methodology references and summaries.

### Key

- Anonymous:** Refers to samples which are not part of this work order, but which formed part of the QC process lot.  
**CAS Number:** Chemical Abstracts Services number is a unique identifier assigned to discrete substances.  
**DQO:** Data Quality Objective.  
**LOR:** Limit of Reporting (detection limit).  
**RPD:** Relative Percent Difference.

### **Workorder Comments**

Holding times are displayed as "----" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

### **Summary of Outliers**

#### **Outliers : Quality Control Samples**

- No Method Blank value outliers occur.
- No Duplicate outliers occur.
- No Laboratory Control Sample (LCS) outliers occur
- No Matrix Spike outliers occur.
- No Test sample Surrogate recovery outliers exist.

#### **Outliers: Reference Material (RM) Samples**

- No Reference Material (RM) Sample outliers occur.

#### **Outliers : Analysis Holding Time Compliance (Breaches)**

- No Analysis Holding Time Outliers exist.

## ***Outliers : Frequency of Quality Control Samples***

- No Quality Control Sample Frequency Outliers occur.



## Analysis Holding Time Compliance

This report summarizes extraction / preparation and analysis times and compares each with ALS recommended holding times, which are selected to meet known provincial and /or federal requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by organizations such as CCME, US EPA, APHA Standard Methods, ASTM, or Environment Canada (where available). Dates and holding times reported below represent the first dates of extraction or analysis. If subsequent tests or dilutions exceeded holding times, qualifiers are added (refer to COA).

If samples are identified below as having been analyzed or extracted outside of recommended holding times, measurement uncertainties may be increased, and this should be taken into consideration when interpreting results.

Where actual sampling date is not provided on the chain of custody, the date of receipt with time at 00:00 is used for calculation purposes.

Where only the sample date without time is provided on the chain of custody, the sampling date at 00:00 is used for calculation purposes.

Matrix: **Water** Evaluation: \* = Holding time exceedance ; ✓ = Within Holding Time

Analyte Group Container / Client Sample ID(s)	Method	Sampling Date	Extraction / Preparation				Analysis			
			Preparation Date	Holding Times		Eval	Analysis Date	Holding Times		Eval
				Rec	Actual			Rec	Actual	
<b>Total Metals : Total Metals in Water by CRC ICPMS</b>										
<b>HDPE - total (lab preserved)</b> Stainless D.F. Beside Rm. 145 Dickens	E420	24-Feb-2022	----	----	----		06-Mar-2022	180 days	10 days	✓
<b>Total Metals : Total Metals in Water by CRC ICPMS</b>										
<b>HDPE - total (lab preserved)</b> Stainless D.F. Beside Rm. 159 Dickens	E420	24-Feb-2022	----	----	----		06-Mar-2022	180 days	10 days	✓
<b>Total Metals : Total Metals in Water by CRC ICPMS</b>										
<b>HDPE - total (lab preserved)</b> Stainless D.F. East of Rm. 210 Dickens	E420	24-Feb-2022	----	----	----		06-Mar-2022	180 days	10 days	✓
<b>Total Metals : Total Metals in Water by CRC ICPMS</b>										
<b>HDPE - total (lab preserved)</b> Stainless D.F. West of Rm. 242 Dickens	E420	24-Feb-2022	----	----	----		06-Mar-2022	180 days	10 days	✓
<b>Total Metals : Total Metals in Water by CRC ICPMS</b>										
<b>HDPE - total (lab preserved)</b> Bottle Fill Opposite Rm. 128 Dickens	E420	24-Feb-2022	----	----	----		05-Mar-2022	180 days	9 days	✓
<b>Total Metals : Total Metals in Water by CRC ICPMS</b>										
<b>HDPE - total (lab preserved)</b> Stainless D.F. Beside 114 Dickens	E420	24-Feb-2022	----	----	----		05-Mar-2022	180 days	9 days	✓

### Legend & Qualifier Definitions

Rec. HT: ALS recommended hold time (see units).



## Quality Control Parameter Frequency Compliance

The following report summarizes the frequency of laboratory QC samples analyzed within the analytical batches (QC lots) in which the submitted samples were processed. The actual frequency should be greater than or equal to the expected frequency.

Matrix: **Water** Evaluation: ✖ = QC frequency outside specification; ✔ = QC frequency within specification.

Quality Control Sample Type	Method	QC Lot #	Count		Frequency (%)		Evaluation
			QC	Regular	Actual	Expected	
<b>Analytical Methods</b>							
<b>Laboratory Duplicates (DUP)</b>							
Total Metals in Water by CRC ICPMS	E420	424701	2	37	5.4	5.0	✔
<b>Laboratory Control Samples (LCS)</b>							
Total Metals in Water by CRC ICPMS	E420	424701	2	37	5.4	5.0	✔
<b>Method Blanks (MB)</b>							
Total Metals in Water by CRC ICPMS	E420	424701	2	37	5.4	5.0	✔
<b>Matrix Spikes (MS)</b>							
Total Metals in Water by CRC ICPMS	E420	424701	2	37	5.4	5.0	✔



## Methodology References and Summaries

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Reference methods may incorporate modifications to improve performance (indicated by "mod").

Analytical Methods	Method / Lab	Matrix	Method Reference	Method Descriptions
Total Metals in Water by CRC ICPMS	E420  Vancouver - Environmental	Water	EPA 200.2/6020B (mod)	Water samples are digested with nitric and hydrochloric acids, and analyzed by Collision/Reaction Cell ICPMS.  Method Limitation (re: Sulfur): Sulfide and volatile sulfur species may not be recovered by this method.





## QUALITY CONTROL REPORT

Work Order : **VA22A3804**

Page : 1 of 4

Client : Vancouver School Board  
Contact : Stephen Thomas  
Address : 1549 Clark Drive  
Vancouver BC Canada V5L 3L4  
Telephone : ----  
Project : ----  
PO : ----  
C-O-C number : 20-986565  
Sampler : Robin LeMay  
Site : ----  
Quote number : ----  
No. of samples received : 6  
No. of samples analysed : 6

Laboratory : Vancouver - Environmental  
Account Manager : Tasnia Tarannum  
Address : 8081 Lougheed Highway  
Burnaby, British Columbia Canada V5A 1W9  
Telephone : +1 604 253 4188  
Date Samples Received : 24-Feb-2022 15:00  
Date Analysis Commenced : 05-Mar-2022  
Issue Date : 10-Mar-2022 16:41

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Quality Control Report contains the following information:

- Laboratory Duplicate (DUP) Report; Relative Percentage Difference (RPD) and Acceptance Limits
- Matrix Spike (MS) Report; Recovery and Acceptance Limits
- Reference Material (RM) Report; Recovery and Acceptance Limits
- Method Blank (MB) Report; Recovery and Acceptance Limits
- Laboratory Control Sample (LCS) Report; Recovery and Acceptance Limits

### Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories	Position	Laboratory Department
Angela Ren	Team Leader - Metals	Metals, Burnaby, British Columbia
Kevin Duarte	Supervisor - Metals ICP Instrumentation	Metals, Burnaby, British Columbia



## General Comments

The ALS Quality Control (QC) report is optionally provided to ALS clients upon request. ALS test methods include comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against predetermined Data Quality Objectives (DQOs) to provide confidence in the accuracy of associated test results. This report contains detailed results for all QC results applicable to this sample submission. Please refer to the ALS Quality Control Interpretation report (QCI) for applicable method references and methodology summaries.

Key :

- Anonymous = Refers to samples which are not part of this work order, but which formed part of the QC process lot.
- CAS Number = Chemical Abstracts Services number is a unique identifier assigned to discrete substances.
- DQO = Data Quality Objective.
- LOR = Limit of Reporting (detection limit).
- RPD = Relative Percentage Difference
- # = Indicates a QC result that did not meet the ALS DQO.

## Workorder Comments

Holding times are displayed as "----" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

## Laboratory Duplicate (DUP) Report

A Laboratory Duplicate (DUP) is a randomly selected intralaboratory replicate sample. Laboratory Duplicates provide information regarding method precision and sample heterogeneity. ALS DQOs for Laboratory Duplicates are expressed as test-specific limits for Relative Percent Difference (RPD), or as an absolute difference limit of 2 times the LOR for low concentration duplicates within ~ 4-10 times the LOR (cut-off is test specific).

Sub-Matrix: <b>Water</b>					<b>Laboratory Duplicate (DUP) Report</b>						
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	LOR	Unit	Original Result	Duplicate Result	RPD(%) or Difference	Duplicate Limits	Qualifier
<b>Total Metals (QC Lot: 424701)</b>											
VA22A3770-001	Anonymous	lead, total	7439-92-1	E420	0.000500	mg/L	0.000608	0.000599	0.000009	Diff <2x LOR	----
<b>Total Metals (QC Lot: 424769)</b>											
VA22A3804-003	Stainless D.F. Beside Rm. 145 Dickens	lead, total	7439-92-1	E420	0.000050	mg/L	0.000750	0.000778	3.64%	20%	----



### Method Blank (MB) Report

A Method Blank is an analyte-free matrix that undergoes sample processing identical to that carried out for test samples. Method Blank results are used to monitor and control for potential contamination from the laboratory environment and reagents. For most tests, the DQO for Method Blanks is for the result to be < LOR.

Sub-Matrix: **Water**

Analyte	CAS Number	Method	LOR	Unit	Result	Qualifier
<b>Total Metals (QCLot: 424701)</b>						
lead, total	7439-92-1	E420	0.00005	mg/L	<0.000050	----
<b>Total Metals (QCLot: 424769)</b>						
lead, total	7439-92-1	E420	0.00005	mg/L	<0.000050	----

### Laboratory Control Sample (LCS) Report

A Laboratory Control Sample (LCS) is an analyte-free matrix that has been fortified (spiked) with test analytes at known concentration and processed in an identical manner to test samples. LCS results are expressed as percent recovery, and are used to monitor and control test method accuracy and precision, independent of test sample matrix.

Sub-Matrix: **Water**

					Laboratory Control Sample (LCS) Report				
					Spike	Recovery (%)	Recovery Limits (%)		
Analyte	CAS Number	Method	LOR	Unit	Concentration	LCS	Low	High	Qualifier
<b>Total Metals (QCLot: 424701)</b>									
lead, total	7439-92-1	E420	0.00005	mg/L	0.5 mg/L	105	80.0	120	----
<b>Total Metals (QCLot: 424769)</b>									
lead, total	7439-92-1	E420	0.00005	mg/L	0.5 mg/L	106	80.0	120	----

### Matrix Spike (MS) Report

A Matrix Spike (MS) is a randomly selected intra-laboratory replicate sample that has been fortified (spiked) with test analytes at known concentration, and processed in an identical manner to test samples. Matrix Spikes provide information regarding analyte recovery and potential matrix effects. MS DQO exceedances due to sample matrix may sometimes be unavoidable; in such cases, test results for the associated sample (or similar samples) may be subject to bias. ND – Recovery not determined, background level >= 1x spike level.

Sub-Matrix: **Water**

					Matrix Spike (MS) Report					
					Spike		Recovery (%)	Recovery Limits (%)		
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	Concentration	Target	MS	Low	High	Qualifier
<b>Total Metals (QCLot: 424701)</b>										
VA22A3741-002	Anonymous	lead, total	7439-92-1	E420	0.0204 mg/L	0.02 mg/L	102	70.0	130	----
<b>Total Metals (QCLot: 424769)</b>										
VA22A3804-004	Stainless D.F. Beside Rm.159 Dickens	lead, total	7439-92-1	E420	0.0184 mg/L	0.02 mg/L	92.2	70.0	130	----



Chain of Custody (COC) / Analytical Request Form

COC Number: 20-986565




www.alsglobal.com

Canada Toll Free: 1 800 668 9878

Page

Environmental Division  
Vancouver  
Work Order Reference  
**VA22A3804**



Telephone: +1 604 253 4166

Report To		Contact and company name below will appear on the final report		Reports / Recipients		Turnaround Time (TAT) Requested	
Company:	Vancouver School Board		Select Report Format:	<input checked="" type="checkbox"/> PDF	<input type="checkbox"/> EXCEL	<input type="checkbox"/> EDD (DIGITAL)	<input checked="" type="checkbox"/> Routine [R] if received by 3pm M-F - no surcharges apply
Contact:	Stephen Thomas		Merge QC/QCI Reports with COA	<input type="checkbox"/> YES	<input type="checkbox"/> NO	<input type="checkbox"/> N/A	<input type="checkbox"/> 4 day [P4] if received by 3pm M-F - 20% rush surcharge minimum
Phone:	604 713 5637		<input type="checkbox"/> Compare Results to Criteria on Report - provide details below if box checked				<input type="checkbox"/> 3 day [P3] if received by 3pm M-F - 25% rush surcharge minimum
Company address below will appear on the final report				Select Distribution:	<input type="checkbox"/> EMAIL	<input type="checkbox"/> MAIL	<input type="checkbox"/> FAX
Street:	1549 Clark Dr.		Email 1 or Fax:	ssthomas@vsb.bc.ca			<input type="checkbox"/> 2 day [P2] if received by 3pm M-F - 50% rush surcharge minimum
City/Province:	Vancouver B.C.		Email 2:				<input type="checkbox"/> 1 day [E] if received by 3pm M-F - 100% rush surcharge minimum
Postal Code:	V5L 3L4		Email 3:				<input type="checkbox"/> Same day [E2] if received by 10am M-S - 200% rush surcharge. Additional fee may apply to rush requests on weekends, statutory holidays and non-routine test
Invoice To:	Same as Report To	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	Invoice Recipients		Date and Time Required for all E&P TATs:	
	Copy of Invoice with Report	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	Select Invoice Distribution:	<input type="checkbox"/> EMAIL	<input type="checkbox"/> MAIL	<input type="checkbox"/> FAX
Company:			Email 1 or Fax:			Analysis Request	
Contact:			Email 2:			For all tests with rush TATs requested, please contact	
Project Information				Oil and Gas Required Fields (client use)			
ALS Account # / Quote #:			AFE/Cost Center:			Indicate Filtered (F), Preserved (P) or Filtered and Preserved (F/P) below	
Job #:			Major/Minor Code:			Routing Code:	
PO / AFE:			Requisitioner:				
LSD:			Location:				
ALS Lab Work Order # (ALS use only):			ALS Contact:	T. Taramon		Sampler:	R. Lemay
ALS Sample # (ALS use only)	Sample Identification and/or Coordinates (This description will appear on the report)		Date (dd-mmm-yy)	Time (hh:mm)	Sample Type	NUMBER OF CONTAINERS Lead	SAMPLES ON HOLD EXTENDED STORAGE REQUIRED SUSPECTED HAZARD (see notes)
1	Bottle Fill Opposite Rm. 128 Dickens		24-02-22	7:37am	Water		
2	Stainless D.F. Beside 114 Dickens		24-02-22	7:41am	Water		
3	Stainless D.F. Beside Rm. 145 Dickens		24-02-22	7:45am	Water		
4	Stainless D.F. Beside Rm. 159 Dickens		24-02-22	7:49am	Water		
5	Stainless D.F. West of Rm. 242 Dickens		24-02-22	7:52am	Water		
6	Stainless D.F. East of Rm. 240 Dickens		24-02-22	7:55am	Water		
Drinking Water (DW) Samples (client use)			Notes / Specify Limits for result evaluation by selecting from drop-down below (Excel COC only)			SAMPLE RECEIPT DETAILS (ALS use only)	
Are samples taken from a Regulated DW System? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO						Cooling Method: <input type="checkbox"/> NONE <input type="checkbox"/> ICE <input type="checkbox"/> ICE PACKS <input type="checkbox"/> FROZEN <input type="checkbox"/> COOLING INITIATED	
Are samples for human consumption/ use? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO						Submission Comments identified on Sample Receipt Notification: <input type="checkbox"/> YES <input type="checkbox"/> NO	
						Cooler Custody Seals Intact: <input type="checkbox"/> YES <input type="checkbox"/> N/A Sample Custody Seals Intact: <input type="checkbox"/> YES <input type="checkbox"/> N/A	
						INITIAL COOLER TEMPERATURES °C: _____ FINAL COOLER TEMPERATURES °C: _____	
SHIPMENT RELEASE (client use)			INITIAL SHIPMENT RECEPTION (ALS use only)			FINAL SHIPMENT RECEPTION (ALS use only)	
Released by:	Date:	Time:	Received by:	Date:	Time:	Received by:	Date: 24 Feb Time: 15:00

White Paper Co. 604 951-3900

REFER TO BACK PAGE FOR ALS LOCATIONS AND SAMPLING INFORMATION

WHITE - LABORATORY COPY YELLOW - CLIENT COPY

Failure to complete all portions of this form may delay analysis. Please fill in this form LEGIBLY. By the use of this form the user acknowledges and agrees with the Terms and Conditions as specified on the back page of the white - report copy.

1. If any water samples are taken from a Regulated Drinking Water (DW) System, please submit using an Authorized DW COC form.

AUG 2020 FRONT

Results Summary VA22A3804								
<b>Project</b>								
<b>Report To</b>	Stephen Thomas, Vancouver School Board							
<b>Date Received</b>	24-Feb-2022 15:00							
<b>Issue Date</b>	10-Mar-2022 16:41							
<b>Amendment</b>	0							
<b>Client Sample ID</b>			Bottle Fill Opposite Rm. 128 Dickens	Stainless D.F. Beside 114 Dickens	Stainless D.F. Beside Rm. 145 Dickens	Stainless D.F. Beside Rm.159 Dickens	Stainless D.F. West of Rm. 242 Dickens	Stainless D.F. East of Rm. 210 Dickens
<b>Date Sampled</b>			24-Feb-2022	24-Feb-2022	24-Feb-2022	24-Feb-2022	24-Feb-2022	24-Feb-2022
<b>Time Sampled</b>			07:37	07:41	07:45	07:49	07:52	07:55
<b>ALS Sample ID</b>			VA22A3804-001	VA22A3804-002	VA22A3804-003	VA22A3804-004	VA22A3804-005	VA22A3804-006
<b>Analyte</b>	Lowest Detection Limit	Units	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water
<b>Total Metals (Matrix: Water)</b>								
lead, total	0.000050	mg/L	0.000101	0.00167	0.000750	0.000134	0.000314	0.000178