



VANCOUVER SCHOOL BOARD  
ATTN: Facilities  
Maintenance and Construction  
1549 Clark Drive  
Vancouver BC V5L 3L4

Date Received: 18-MAY-16  
Report Date: 27-MAY-16 18:18 (MT)  
Version: FINAL

Client Phone: --

## Certificate of Analysis

**Lab Work Order #:** L1770897  
**Project P.O. #:** NOT SUBMITTED  
**Job Reference:**  
**C of C Numbers:** 15-563382, 15-563383, 15-563396  
**Legal Site Desc:**

**Comments:** Report separated by school.

Dean Watt, B.Sc.  
Account Manager

[This report shall not be reproduced except in full without the written authority of the Laboratory.]

ADDRESS: 8081 Lougheed Hwy, Suite 100, Burnaby, BC V5A 1W9 Canada | Phone: +1 604 253 4188 | Fax: +1 604 253 6700  
ALS CANADA LTD Part of the ALS Group A Campbell Brothers Limited Company

# ALS ENVIRONMENTAL ANALYTICAL REPORT

		Sample ID	L1770897-10	L1770897-13	L1770897-14		
		Description	Water	Water	Water		
		Sampled Date	18-MAY-16	18-MAY-16	18-MAY-16		
		Sampled Time	10:00	09:50	09:40		
		Client ID	MACCORKINGDAL E 129A-DF	MACCORKINGDAL E 107-SINK	MACCORKINGDAL E 139-DF		
Grouping	Analyte						
<b>WATER</b>							
Total Metals	Lead (Pb)-Total (mg/L)	0.000873	0.000365	0.00632			