

## Results Summary VA23C4211

**Project** Elsie Roy Elementary  
**Report To** Stephen Thomas, Vancouver School Board  
**Date Received** 11-Oct-2023 14:55  
**Issue Date** 20-Oct-2023 19:49  
**Amendment** 0

Client Sample ID			Corr. 200 Room 214 SSDF	Corr. 113 Opposite Rm.125 Bottle Fill	Opposite Rm. 121 SSDF
Date Sampled			11-Oct-2023	11-Oct-2023	11-Oct-2023
Time Sampled			07:47	07:51	07:54
ALS Sample ID			VA23C4211-001	VA23C4211-002	VA23C4211-003
Analyte	Lowest Detection Limit	Units	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water
<b>Total Metals (Matrix: Water)</b>					
Lead, total	0.000050	mg/L	0.00100	0.000225	0.000190