

Results Summary VA23C4633

Project False Creek Elementary
Report To Stephen Thomas, Vancouver School Board
Date Received 16-Oct-2023 15:00
Issue Date 23-Oct-2023 08:24
Amendment 0

Client Sample ID			Corr. 114 Rm 112 S.S.D.F	Vest. 109 Opposite Rm 108 S.S.D.F	Stair 295 Rm 216 S.S.D.F
Date Sampled			16-Oct-2023	16-Oct-2023	16-Oct-2023
Time Sampled			08:32	08:38	08:45
ALS Sample ID			VA23C4633-001	VA23C4633-002	VA23C4633-003
Analyte	Lowest Detection Limit	Units	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water
Total Metals (Matrix: Water)					
Lead, total	0.000050	mg/L	0.00106	0.00195	0.000984