ALS Canada Ltd.

Contact



CERTIFICATE OF ANALYSIS (GUIDELINE EVALUATION)

: VA22C9231 Work Order Page : 1 of 3

Client Laboratory : Vancouver - Environmental : Vancouver School Board

: Stephen Thomas **Account Manager** : Tasnia Tarannum Address Address

: 1549 Clark Drive : 8081 Lougheed Highway

Vancouver BC Canada V5L 3L4 Burnaby, British Columbia Canada V5A 1W9

Telephone Telephone : +1 604 253 4188 : ----Project : Grenfell Elementary **Date Samples Received** : 01-Dec-2022 16:39

Date Analysis Commenced : 02-Dec-2022 PO

: 05-Dec-2022 10:18 C-O-C number : 20-1039079 Issue Date Sampler : k.Messamore

Site Quote number No. of samples received : 8 No. of samples analysed : 8

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results
- Guideline Comparison

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories Position Laboratory Department

Kim Jensen Department Manager - Metals Metals, Burnaby, British Columbia Page : 2 of 3 Work Order : VA22C9231

Client : Vancouver School Board

Project : Grenfell Elementary



No Breaches Found

General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information. Guidelines are not adjusted for the hardness, pH or temperature of the sample (the most conservative values are used). Measurement uncertainty is not applied to test results prior to comparison with specified criteria values.

Key: LOR: Limit of Reporting (detection limit).

Unit	Description
mg/L	milligrams per litre

>: greater than.

Red shading is applied where the result is greater than the Guideline Upper Limit or the result is lower than the Guideline Lower Limit.

For drinking water samples, Red shading is applied where the result for E.coli, fecal or total coliforms is greater than or equal to the Guideline Upper Limit.

<: less than.

Page : 3 of 3 Work Order : VA22C9231

Client : Vancouver School Board

Project : Grenfell Elementary



Analytical Results Evaluation

Matrix:										
	Sampling date/time									
	Sub-Matri									
Analyte	CAS Number	Unit								
		-								
Please refer to the General Comments section for an explanation of any qualifiers detected.										
lead, total		7439-92-1	mg/L							



QUALITY CONTROL INTERPRETIVE REPORT

Work Order : **VA22C9231** Page : 1 of 6

Client : Vancouver School Board Laboratory : Vancouver - Environmental

Contact : Stephen Thomas Account Manager : Tasnia Tarannum

Address :1549 Clark Drive Address :8081 Lougheed Highway

Burnaby, British Columbia Canada V5A 1W9

Telephone :---- Telephone :+1 604 253 4188

Project :Grenfell Elementary Date Samples Received :01-Dec-2022 16:39

PO : ---- Issue Date : 05-Dec-2022 10:18

C-O-C number : 20-1039079
Sampler : k.Messamore

Site :---Quote number :---No. of samples received :8
No. of samples analysed :8

This report is automatically generated by the ALS LIMS (Laboratory Information Management System) through evaluation of Quality Control (QC) results and other QA parameters associated with this submission, and is intended to facilitate rapid data validation by auditors or reviewers. The report highlights any exceptions and outliers to ALS Data Quality Objectives, provides holding time details and exceptions, summarizes QC sample frequencies, and lists applicable methodology references and summaries.

Key

Anonymous: Refers to samples which are not part of this work order, but which formed part of the QC process lot.

CAS Number: Chemical Abstracts Service number is a unique identifier assigned to discrete substances.

Vancouver BC Canada V5L 3L4

DQO: Data Quality Objective.

LOR: Limit of Reporting (detection limit).

RPD: Relative Percent Difference.

Workorder Comments

Holding times are displayed as "---" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Summary of Outliers

Outliers : Quality Control Samples

- No Method Blank value outliers occur.
- No Duplicate outliers occur.
- No Laboratory Control Sample (LCS) outliers occur
- No Matrix Spike outliers occur.
- No Test sample Surrogate recovery outliers exist.

Outliers: Reference Material (RM) Samples

No Reference Material (RM) Sample outliers occur.

Outliers: Analysis Holding Time Compliance (Breaches) ■ No Analysis Holding Time Outliers exist.

Outliers: Frequency of Quality Control Samples • No Quality Control Sample Frequency Outliers occur.

Page : 3 of 6 Work Order : VA22C9231

Client : Vancouver School Board Project : Grenfell Elementary



Analysis Holding Time Compliance

This report summarizes extraction / preparation and analysis times and compares each with ALS recommended holding times, which are selected to meet known provincial and/or federal requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by organizations such as CCME, US EPA, APHA Standard Methods, ASTM, or Environment Canada (where available). Dates and holding times reported below represent the first dates of extraction or analysis. If subsequent tests or dilutions exceeded holding times, qualifiers are added (refer to COA).

If samples are identified below as having been analyzed or extracted outside of recommended holding times, measurement uncertainties may be increased, and this should be taken into consideration when interpreting results.

Where actual sampling date is not provided on the chain of custody, the date of receipt with time at 00:00 is used for calculation purposes.

Where only the sample date without time is provided on the chain of custody, the sampling date at 00:00 is used for calculation purposes.

Matrix: Water			Evaluation: × =	Holding time exceedance; ✓ = Within Holding Time
Analysis Overs	A A - 411	On the Parks	Esteration / Decreasing	Amelicaia

Analyte Group	Method	Sampling Date	Ext	raction / Pr	eparation		Analysis			
Container / Client Sample ID(s)			Preparation	Holding	g Times	Eval	Analysis Date	Holding	g Times	Eval
			Date	Rec	Actual			Rec	Actual	
Total Metals : Total metals in Water by CRC ICPMS										
HDPE - total (lab preserved)										
Corr 100 RM 106 SSDF	E420	01-Dec-2022	02-Dec-2022				04-Dec-2022	180	3 days	✓
								days		
Total Metals : Total metals in Water by CRC ICPMS										
HDPE - total (lab preserved)										
Corr 200 RM 200B SSDF	E420	01-Dec-2022	02-Dec-2022				04-Dec-2022	180	3 days	*
								days		
Total Metals : Total metals in Water by CRC ICPMS										
HDPE - total (lab preserved)	E420	01-Dec-2022	02-Dec-2022				04-Dec-2022		0 4	
Corr 200 RM 206 SSDF	E420	01-Dec-2022	02-Dec-2022				04-Dec-2022	180	3 days	"
								days		
Total Metals : Total metals in Water by CRC ICPMS				l I				I	1	
HDPE - total (lab preserved) Corr 200 RM 135 Bottle Filler	E420	01-Dec-2022	02-Dec-2022				04-Dec-2022	180	4 days	
Coll 200 Rivi 133 Bottle Fillel	L420	01-Dec-2022	02-Dec-2022				04-Dec-2022	days	4 days	, ,
								uays		
Total Metals : Total metals in Water by CRC ICPMS HDPE - total (lab preserved)				I						
RM 164 Bubbler	E420	01-Dec-2022	02-Dec-2022				04-Dec-2022	180	4 days	√
NW 10- Bubblet	0	0.200202	02 500 2022				0 1 200 2022	days	raayo	
Total Metals : Total metals in Water by CRC ICPMS										
HDPE - total (lab preserved)										
RM 165 Bubbler	E420	01-Dec-2022	02-Dec-2022				04-Dec-2022	180	4 days	✓
								days	,	
Total Metals : Total metals in Water by CRC ICPMS										
HDPE - total (lab preserved)										
RM 167 Bubbler	E420	01-Dec-2022	02-Dec-2022				04-Dec-2022	180	4 days	✓
								days		
								days		

Page : 4 of 6 Work Order : VA22C9231

Client : Vancouver School Board
Project : Grenfell Elementary



Matrix: Water Evaluation: × = Holding time exceedance; ✓ = Within Holding Time

Evaluation. " - Holding time exceedance; " - Within Holding Time										
Analyte Group	Method	Sampling Date	Ext			Analysis				
Container / Client Sample ID(s)			Preparation	tion Holding Times		Eval	Analysis Date	Holding	g Times	Eval
			Date	Rec	Actual			Rec	Actual	
Total Metals : Total metals in Water by CRC ICPMS										
HDPE - total (lab preserved) RM 168 Bubbler	E420	01-Dec-2022	02-Dec-2022				04-Dec-2022	180 days	4 days	✓

Legend & Qualifier Definitions

Rec. HT: ALS recommended hold time (see units).

Page : 5 of 6 Work Order : VA22C9231

Client : Vancouver School Board Project : Grenfell Elementary



Quality Control Parameter Frequency Compliance

The following report summarizes the frequency of laboratory QC samples analyzed within the analytical batches (QC lots) in which the submitted samples were processed. The actual frequency should be greater than or equal to the expected frequency.

Matrix: Water	Evaluation: * = QC frequency outside specification; < = QC frequency within specification.												
Quality Control Sample Type			Co	unt		Frequency (%)							
Analytical Methods	Method	QC Lot #	QC	Regular	Actual	Expected	Evaluation						
Laboratory Duplicates (DUP)													
Total metals in Water by CRC ICPMS	E420	765697	1	20	5.0	5.0	✓						
Laboratory Control Samples (LCS)													
Total metals in Water by CRC ICPMS	E420	765697	1	20	5.0	5.0	✓						
Method Blanks (MB)													
Total metals in Water by CRC ICPMS	E420	765697	1	20	5.0	5.0	✓						
Matrix Spikes (MS)													
Total metals in Water by CRC ICPMS	E420	765697	1	20	5.0	5.0	✓						

Page : 6 of 6 Work Order : VA22C9231

Client : Vancouver School Board Project : Grenfell Elementary



Methodology References and Summaries

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Reference methods may incorporate modifications to improve performance (indicated by "mod").

Analytical Methods	Method / Lab	Matrix	Method Reference	Method Descriptions
Total metals in Water by CRC ICPMS	E420	Water	EPA 200.2/6020B	Water samples are digested with nitric and hydrochloric acids, and analyzed by
			(mod)	Collision/Reaction Cell ICPMS.
	Vancouver -			
	Environmental			Method Limitation (re: Sulfur): Sulfide and volatile sulfur species may not be recovered
				by this method.

ALS Canada Ltd.



QUALITY CONTROL REPORT

Work Order :VA22C9231

Client : Vancouver School Board

Address : 1549 Clark Drive

Vancouver BC Canada V5L 3L4

: Stephen Thomas

Telephone

Contact

Project : Grenfell Elementary

PO :--

C-O-C number : 20-1039079
Sampler : k.Messamore

 Page : 1 of 3

Laboratory : Vancouver - Environmental

Account Manager : Tasnia Tarannum

Address : 8081 Lougheed Highway

Burnaby, British Columbia Canada V5A 1W9

Telephone :+1 604 253 4188

Date Samples Received :01-Dec-2022 16:39

Date Analysis Commenced : 02-Dec-2022

Issue Date : 05-Dec-2022 10:18

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Quality Control Report contains the following information:

Laboratory Duplicate (DUP) Report; Relative Percent Difference (RPD) and Data Quality Objectives

- Matrix Spike (MS) Report; Recovery and Data Quality Objectives
- Method Blank (MB) Report; Recovery and Data Quality Objectives
- Laboratory Control Sample (LCS) Report; Recovery and Data Quality Objectives

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories Position Laboratory Department

Kim Jensen Department Manager - Metals Vancouver Metals, Burnaby, British Columbia

Page : 2 of 3 Work Order : VA22C9231

Client : Vancouver School Board
Project : Grenfell Elementary



General Comments

The ALS Quality Control (QC) report is optionally provided to ALS clients upon request. ALS test methods include comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against predetermined Data Quality Objectives (DQOs) to provide confidence in the accuracy of associated test results. This report contains detailed results for all QC results applicable to this sample submission. Please refer to the ALS Quality Control Interpretation report (QCI) for applicable method references and methodology summaries.

Key:

Anonymous = Refers to samples which are not part of this work order, but which formed part of the QC process lot.

CAS Number = Chemical Abstracts Service number is a unique identifier assigned to discrete substances.

DQO = Data Quality Objective.

LOR = Limit of Reporting (detection limit).

RPD = Relative Percent Difference

= Indicates a QC result that did not meet the ALS DQO.

Workorder Comments

Holding times are displayed as "---" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Laboratory Duplicate (DUP) Report

A Laboratory Duplicate (DUP) is a randomly selected intralaboratory replicate sample. Laboratory Duplicates provide information regarding method precision and sample heterogeneity. ALS DQOs for Laboratory Duplicates are expressed as test-specific limits for Relative Percent Difference (RPD), or as an absolute difference limit of 2 times the LOR for low concentration duplicates within ~ 4-10 times the LOR (cut-off is test-specific).

Sub-Matrix: Water						Laboratory Duplicate (DUP) Report							
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	LOR	Unit	Original Result	Duplicate Result	RPD(%) or Difference	Duplicate Limits	Qualifier		
Total Metals (QC Lo	Total Metals (QC Lot: 765697)												
VA22C9231-001	RM 167 Bubbler	lead, total	7439-92-1	E420	0.000050	mg/L	0.000138	0.000138	0.0000009	Diff <2x LOR			

Method Blank (MB) Report

A Method Blank is an analyte-free matrix that undergoes sample processing identical to that carried out for test samples. Method Blank results are used to monitor and control for potential contamination from the laboratory environment and reagents. For most tests, the DQO for Method Blanks is for the result to be < LOR.

Sub-Matrix: Water

Analyte	CAS Number	Method	LOR	Unit	Result	Qualifier
Total Metals (QCLot: 765697)						
lead, total	7439-92-1	E420	0.00005	mg/L	<0.000050	

Page : 3 of 3 Work Order : VA22C9231

Client : Vancouver School Board
Project : Grenfell Elementary



Laboratory Control Sample (LCS) Report

A Laboratory Control Sample (LCS) is an analyte-free matrix that has been fortified (spiked) with test analytes at known concentration and processed in an identical manner to test samples. LCS results are expressed as percent recovery, and are used to monitor and control test method accuracy and precision, independent of test sample matrix.

Sub-Matrix: Water	ub-Matrix: Water						Laboratory Control Sample (LCS) Report							
						Recovery (%)	Recovery	Limits (%)						
Analyte	CAS Number	Method	LOR	Unit	Concentration	LCS	Low	High	Qualifier					
Total Metals (QCLot: 765697)														
lead, total	7439-92-1	E420	0.00005	mg/L	0.5 mg/L	97.7	80.0	120						

Matrix Spike (MS) Report

A Matrix Spike (MS) is a randomly selected intra-laboratory replicate sample that has been fortified (spiked) with test analytes at known concentration, and processed in an identical manner to test samples. Matrix Spikes provide information regarding analyte recovery and potential matrix effects. MS DQO exceedances due to sample matrix may sometimes be unavoidable; in such cases, test results for the associated sample (or similar samples) may be subject to bias. ND – Recovery not determined, background level >= 1x spike level.

Sub-Matrix: Water		, , ,	,	, 3	Matrix Spike (MS) Report										
					Spi	ike	Recovery (%)	Recovery							
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	Concentration	Target	MS	Low	High	Qualifier					
Total Metals (QCLot: 765697)															
VA22C9231-002	RM 165 Bubbler	lead, total	7439-92-1	E420	0.0185 mg/L	0.02 mg/L	92.3	70.0	130						

		·	Canada Toll Free: 1 800 668 9878								Page	ربار <u>عالم</u>	of_	uk a t k	4	1.2020	' ;
(ALS)	www.alsglobal.com	· Caller	in in the second	e e	Page 1 State 1 State 2	2 3 8/4 € 6 5 44 €			v e	to the	• • • • • •		11.75° . 1.4.466	i tori.	Je .	C7	
Report To	* Contact and company name below will appear on the final report		Reports / R	ecipients				Turnaroun	d Time (T	AT) Reque	sted		and the same				W
Сотрапу:	VANCOUVER SCHOOL BOAKD - ANT	Select Report Fo	ormat: DP POF [D. EXCEL DE	D (DIGITAL)	Routine	e [R] if re	ceived by 3p	m M-E - n	o surcharges	apply	* *					***
Contact:	STEPHEN THOMAS	Merge QC/QC	I Reports with COA	☐ YES ☐ NK	N/A	☐ 4 dayl	[P4] if rex	eived by 3pm	n M-F -, .20	% rush surc	:harge minimu	m _{o.}					
Phone: *	004-713-5637	+ ☐ ∴Compare Resu	its to Criteria on Report - pr	rovide, details below <u>if</u>	box checked +						charge minim		AFFIX	ALS BARC	JODE LA use only)	5 - Telephone 1	₹E
1	Company address below will appear on the final report	Select Distribution	on: 🗗 EMAIL	MAIL D'	FAX 21 11.7.	_					charge minimi charge minimi	A-12	10 ²⁴				
Street:	1549 CLARR DRIVER	Email 1 or Fax									surcharge. Add		200	A COM		a si	
City/Province:	- VANCOUVER BC	Email 2					ply tarus	requests on	weekends,	statutory holi	idays and non-r	outine tests	1997 1887 - 1980			a e	
Postal Code:		Email 3 Journa Q 1/SD. BC. CA				Date	Date and Time Required for all E&P TATS: # dd-mmm-yy hh:mm am/pm										
Invoice To	Same as Report To 🖺 YES 🗌 NO		Invoice Recipients				For all tests with rush TATs requested, please contact your AM to confirm availability.										
	Copy of Invoice with Report . ☐ YES ☐ NO	Select Invoice Distribution: BMAIL MAIL FAX				Analysis Request											
Company:		Email 1 or Fax	Email 1 or Fax				Indicate Filtered (F), Preserved (P) or Filtered and Preserved (F/P) below										छ
Contact:	mitwell 100 32 - March Line Company	 	Email2 مى سىرىسى خاتى بىرى ئىسى بارى سىرى كالسام				. I III 1 is and an idea of the first term in										ğ
	Project Information — —	9	Oil and Gas Required	l Fields (client us	se)	N N	- i -		4-		5 44		,r.,	1	ے ا	[ត្ត]	. ē
ALS Account # /		AFE/Cost Center:	5 \$ 60 to 2 p	PO#	1 in 4/5 wilds.	<u> -</u> ' '	ar i.ebe A i i i i	1. 19	i K	bs	`	∵ र ।	* *	11.4	1 2	H.	Š
Job#: ** (PRENTEU ELEMENTARY	Major/Minor Code:	emina a no ser no exist	Routing Code:	A S F P TO BURE	5 "	*C + ::	ins 1	مند کا ایک	1,31Q (6)			16 7		기	JGE	HAZARD (see
PO / AFE:	والمراج والمناز والمحاجر	Requisitioner:	المشاه والما	ونعدر المعدو	روروهم والإفادان والسم		1 1		. 1	ins:		1 500		e meg	S	%	βl
LSD: +	and men the property of the second se	Location: 2000	يئ هر الأراجيدي العر	The manager to	இச் நக்க	ō ∢	(la fare	1.7	1 10	40	t bred at	أحارر	े ₌	100	٠ %	ST.	
ALS Lab Work	Order# (ALS use only):	ALS Contact:	T. Jarannum	Sampler: K	Messamure	BER) total	1 100 PM		ft a	ntal Divi	sion	12.78 A 14				ECTED
ALS Sample #	Sample Identification and/or Coordinates		, Date	Time	Sample Type	[]	ii p stês 1	int -	21	* -*	ital Div		1/2.3		- I ∑		S.
(ALS use only)	(This description will appear on the report)	· .	(dd-mmm-yy)	(hh:mm)	Sample Type	⊋	5 40	سرايد مودا		'ouwe	,	euce C	\ \		√S	ũ	<u>8</u>
	RM 167 Bubbler 100	502/14 Lat	01-DEC-22	7:30	Water	1 2 2 2		14	EUNI	Mork Or ICONAG	5.5c.	2/2/2	•	\	36	7	
2	RM 165 Bubbler	Here	01-DEC-22	7:35	water			Ting .	Var	MOLKO	ñQU	J .	/// //	V4 30	14, d a		-7-4 2
· 3	RM 164 Bubbler		01-066-22	7:40	Water			<u>Γ</u>		JP		. 111		\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\			r > 1
, U%,	RM 168 Bubbler -	3 JE . S	01-DEC-22	7:45	Water		-					4112		7		j., £41	
		Filler	01-DEC-12	7:50	Mater		١,		i na		B. T	11/2	3 111	7 4			
6		348 a 1 2548	01-DEC-22	7:55	Water		4.		<u> </u>	- 1	111 150.3	1.12.1	(1 4 P.)	. \	7	1 ,57	51
* 7°	Corr 200 RM. 206 SSDF .		01-DE(-22		water		-					~1 604 25	6874 S	. 1			
¥ .	COLL 100 - LW -101 - SSDE.	<u>Turing dia kanananan dia</u> Prinsi dia Nasa dia kanananan	01-DEC-22	8:05	Water	·z					111 24	7 604 25	ر 10 مارس	5 13			
LIF SE	The figure of the first of the	AA - 41 PM - 3 W -	1 000-00	273-	00000		++		er programme	ì	- alephone	· -1		+++	-	35	
7 % 30	the court of the c	ا به جومیه اس در و						193	ing #	<u> </u>	/a.			+++	+	+	
₹#₹	4.100	¥ 10.55		•		 	+			 		3-		+ +	+	╁┷┪	4.
					3 35	-	+			k k	11.1.7	+	_	+-+	+	+	一!
. T in	Notes / Specif	he Limite for recult	avaluation by colorting	from drop down	holow	3000 A		284	SAM	PIFREC	EIPT DET	All S (Al S	use only	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		7000 7700	2200
‡ Drinking	Water (DW) Samples ¹ (client use)		Limits for result evaluation by selecting from drop-down below (Excel COC only)					# □ ®ix			ICE PACKS						
Are samples taken	from a Regulated DW System? (1749)	· · · · · · · ·	and the first of t								Receipt Not		1. 660-100	JYES -	Edition In Edit	to effected	
Æ YE	BOTH NOTES OF THE STATE OF THE	and the State of t	The State of Lands	and the second	96	100011 4411	26-1-	Seals Intac			□ N/A S	continue in the			S	res 🖂	NA A
Are samples for hi	iman consumption/use?	pre servatives added			22.88 M. Sec.				URES °C			FINAL COOL					
YES	1 NO 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	The state of the s				P. Carlot		\$ j	ill.	1	Town Market	ă și		ray gr	. See	8.	30°F
	SHIPMENT RELEASE (client use)		INITIAL SHIPMENT	RECEPTION (A	LS use only) ∰	NAME OF STREET	· ·	. 1886° - 1	di s	FINAL SI	IPMENT R	ECEPTIO	N (ALS u	se only)	77°	. P	38
Released by:	Date: Time:	Received by:		Date:		Time:	Rec	eived by:	E		Date:	1117	717	7	Tim	e: • ζ	0

REFER TO BACK PAGE FOR ALS LOCATIONS AND SAMPLING INFORMATION

WHITE - LABORATORY COPY YELLOW - CLIENT COPY

Failure to complete all portions of this form may delay analysis. Please fill in this form LEGIBLY. By the use of this form the user acknowledges and agrees with the Terms and Conditions as specified on the back page of the white - report copy, 1. If any water samples are taken from a Regulated Drinking Water (DW) System, please submit using an Authorized DW COC form.

Results Summary VA22C9231

Project Grenfell Elementary

Report To Stephen Thomas, Vancouver School Board

 Date Received
 01-Dec-2022 16:39

 Issue Date
 05-Dec-2022 10:18

Amendment

Client Sample ID			RM 167 Bubbler	RM 165 Bubbler	RM 164 Bubbler	RM 168 Bubbler	Corr 200 RM 135 Bottle Filler	Corr 200 RM 200B SSDF	Corr 200 RM 206 SSDF	Corr 100 RM 106 SSDF
Date Sampled			01-Dec-2022	01-Dec-2022	01-Dec-2022	01-Dec-2022	01-Dec-2022	01-Dec-2022	01-Dec-2022	01-Dec-2022
Time Sampled			07:30	07:35	07:40	07:45	07:50	07:55	08:00	08:05
ALS Sample ID			VA22C9231-001	VA22C9231-002	VA22C9231-003	VA22C9231-004	VA22C9231-005	VA22C9231-006	VA22C9231-007	VA22C9231-008
Analyte	Lowest Detection Limit	Units	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water
Total Metals (Matrix: Water)										
lead, total	0.000050	mg/L	0.000138	< 0.000050	0.000088	0.000184	0.000291	0.00208	0.000947	0.000932