

Results Summary VA23C5984

Project Hastings Elementary
Report To Stephen Thomas, Vancouver School Board
Date Received 27-Oct-2023 15:05
Issue Date 06-Nov-2023 08:39
Amendment 0

Client Sample ID			Corr. 022 Rm. 018 D.F.	Corr. 022 Rm. 010 D.F.	Corr. 119 Rm. 112 D.F.	Corr. 119 Rm. 117 D.F.	Corr. 121 Rm. 126 S.S.B.F.	Corr. 217 Rm. 212 D.F.	Corr. 217 Rm. 215 D.F.
Date Sampled			27-Oct-2023	27-Oct-2023	27-Oct-2023	27-Oct-2023	27-Oct-2023	27-Oct-2023	27-Oct-2023
Time Sampled			07:25	07:30	07:35	07:39	07:41	07:48	07:50
ALS Sample ID			VA23C5984-001	VA23C5984-002	VA23C5984-003	VA23C5984-004	VA23C5984-005	VA23C5984-006	VA23C5984-007
Analyte	Lowest Detection Limit	Units	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water
Total Metals (Matrix: Water)									
Lead, total	0.000050	mg/L	0.000480	0.000679	0.000491	0.000091	0.000788	0.000436	0.000134