ALS Canada Ltd.



CERTIFICATE OF ANALYSIS (GUIDELINE EVALUATION)

: VA22C9812 **Work Order** Page : 1 of 3

Client Laboratory : Vancouver - Environmental : Vancouver School Board

Contact : Stephen Thomas **Account Manager** : Tasnia Tarannum Address

: 1549 Clark Drive Address : 8081 Lougheed Highway Vancouver BC Canada V5L 3L4

Burnaby, British Columbia Canada V5A 1W9

Telephone Telephone : +1 604 253 4188 : ----Project : Hastings Elementary **Date Samples Received** : 08-Dec-2022 14:55

Date Analysis Commenced : 10-Dec-2022

: 13-Dec-2022 10:12 C-O-C number : 20-1039077 Issue Date

Sampler Site : ----Quote number No. of samples received : 7 No. of samples analysed : 7

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results
- Guideline Comparison

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

Signatories

PO

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories Position Laboratory Department

Kim Jensen Department Manager - Metals Metals, Burnaby, British Columbia Page : 2 of 3 Work Order · VA22C9812

Client : Vancouver School Board

Project : Hastings Elementary



No Breaches Found

General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information. Guidelines are not adjusted for the hardness, pH or temperature of the sample (the most conservative values are used). Measurement uncertainty is not applied to test results prior to comparison with specified criteria values.

Key: LOR: Limit of Reporting (detection limit).

Unit	Description
mg/L	milligrams per litre

>: greater than.

Red shading is applied where the result is greater than the Guideline Upper Limit or the result is lower than the Guideline Lower Limit.

For drinking water samples, Red shading is applied where the result for E.coli, fecal or total coliforms is greater than or equal to the Guideline Upper Limit.

<: less than.

Page

3 of 3 VA22C9812 Work Order

Client Vancouver School Board

Hastings Elementary Project



Analytical Results Evaluation

Matrix:	Clie	nt sample ID		 	 	
	Sampling date/time			 	 	
Analyte	CAS Number	Unit		 	 	
		-				
Please refer to the General Comments section for a	ın explanation of any	qualifiers det	ected.			
lead, total		7439-92-1	mg/L			



QUALITY CONTROL INTERPRETIVE REPORT

Work Order : **VA22C9812** Page : 1 of 6

Client : Vancouver School Board Laboratory : Vancouver - Environmental

Contact : Stephen Thomas Account Manager : Tasnia Tarannum

Address :1549 Clark Drive Address :8081 Lougheed Highway

Burnaby, British Columbia Canada V5A 1W9

Telephone :---- Telephone :+1 604 253 4188

Project :Hastings Elementary Date Samples Received :08-Dec-2022 14:55

PO : ---- Issue Date : 13-Dec-2022 10:11 C-O-C number : 20-1039077

Sampler :--Site :--Quote number :--No. of samples received :7
No. of samples analysed :7

This report is automatically generated by the ALS LIMS (Laboratory Information Management System) through evaluation of Quality Control (QC) results and other QA parameters associated with this submission, and is intended to facilitate rapid data validation by auditors or reviewers. The report highlights any exceptions and outliers to ALS Data Quality Objectives, provides holding time details and exceptions, summarizes QC sample frequencies, and lists applicable methodology references and summaries.

Key

Anonymous: Refers to samples which are not part of this work order, but which formed part of the QC process lot.

CAS Number: Chemical Abstracts Service number is a unique identifier assigned to discrete substances.

Vancouver BC Canada V5L 3L4

DQO: Data Quality Objective.

LOR: Limit of Reporting (detection limit).

RPD: Relative Percent Difference.

Workorder Comments

Holding times are displayed as "---" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Summary of Outliers

Outliers: Quality Control Samples

- No Method Blank value outliers occur.
- No Duplicate outliers occur.
- No Laboratory Control Sample (LCS) outliers occur
- No Matrix Spike outliers occur.
- No Test sample Surrogate recovery outliers exist.

Outliers: Reference Material (RM) Samples

No Reference Material (RM) Sample outliers occur.

Outliers: Analysis Holding Time Compliance (Breaches) ■ No Analysis Holding Time Outliers exist.

Outliers: Frequency of Quality Control Samples • No Quality Control Sample Frequency Outliers occur.

Page : 3 of 6 Work Order : VA22C9812

Matrix: Water

Analyte Group

Container / Client Sample ID(s)

HDPE - total (lab preserved)

Corr 217 Rm 215 SSDF

HDPE - total (lab preserved)

Corr 217 Rm 312 DF

Total Metals: Total metals in Water by CRC ICPMS

Client : Vancouver School Board
Project : Hastings Elementary



Eval

Evaluation: **x** = Holding time exceedance; ✓ = Within Holding Time

Analysis Date

11-Dec-2022

11-Dec-2022

Analysis

Rec

Holding Times

Actual

Analysis Holding Time Compliance

This report summarizes extraction / preparation and analysis times and compares each with ALS recommended holding times, which are selected to meet known provincial and/or federal requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by organizations such as CCME, US EPA, APHA Standard Methods, ASTM, or Environment Canada (where available). Dates and holding times reported below represent the first dates of extraction or analysis. If subsequent tests or dilutions exceeded holding times, qualifiers are added (refer to COA).

If samples are identified below as having been analyzed or extracted outside of recommended holding times, measurement uncertainties may be increased, and this should be taken into consideration when interpreting results.

Sampling Date

Method

E420

E420

Extraction / Preparation

Rec

Preparation

Date

10-Dec-2022

10-Dec-2022

Holding Times

Actual

Eval

Where actual sampling date is not provided on the chain of custody, the date of receipt with time at 00:00 is used for calculation purposes.

Where only the sample date without time is provided on the chain of custody, the sampling date at 00:00 is used for calculation purposes.

Total Metals: Total metals in Water by CRC ICPMS HDPE - total (lab preserved) E420 10-Dec-2022 11-Dec-2022 ✓ Corr 022 Rm 014A DF 08-Dec-2022 180 3 days days Total Metals: Total metals in Water by CRC ICPMS HDPE - total (lab preserved) Corr 022 Rm 018 SSDF E420 08-Dec-2022 10-Dec-2022 11-Dec-2022 3 days 180 days Total Metals: Total metals in Water by CRC ICPMS HDPE - total (lab preserved) E420 08-Dec-2022 ✓ Corr 119 Rm 112 DF 10-Dec-2022 11-Dec-2022 3 days 180 days Total Metals: Total metals in Water by CRC ICPMS HDPE - total (lab preserved) Corr 119 Rm 117 SSDF E420 08-Dec-2022 10-Dec-2022 11-Dec-2022 180 3 davs days Total Metals: Total metals in Water by CRC ICPMS HDPE - total (lab preserved) E420 08-Dec-2022 10-Dec-2022 11-Dec-2022 1 Corr 121 Rm 136 Bottle Filler 180 3 days days Total Metals: Total metals in Water by CRC ICPMS

08-Dec-2022

08-Dec-2022

3 days

3 days

180

davs

180 days ✓

✓

 Page
 :
 4 of 6

 Work Order
 :
 VA22C9812

Client : Vancouver School Board Project : Hastings Elementary



Legend & Qualifier Definitions

Rec. HT: ALS recommended hold time (see units).

Page : 5 of 6 Work Order : VA22C9812

Client : Vancouver School Board Project : Hastings Elementary



Quality Control Parameter Frequency Compliance

The following report summarizes the frequency of laboratory QC samples analyzed within the analytical batches (QC lots) in which the submitted samples were processed. The actual frequency should be greater than or equal to the expected frequency.

Matrix: Water	er Evaluation: × = QC frequency outside specification, ✓ = QC frequency within specific												
Quality Control Sample Type			Co	ount)							
Analytical Methods	Method	QC Lot #	QC	Regular	Actual	Expected	Evaluation						
Laboratory Duplicates (DUP)													
Total metals in Water by CRC ICPMS	E420	772887	1	19	5.2	5.0	✓						
Laboratory Control Samples (LCS)													
Total metals in Water by CRC ICPMS	E420	772887	1	19	5.2	5.0	✓						
Method Blanks (MB)													
Total metals in Water by CRC ICPMS	E420	772887	1	19	5.2	5.0	✓						
Matrix Spikes (MS)													
Total metals in Water by CRC ICPMS	E420	772887	1	19	5.2	5.0	✓						

Page : 6 of 6 Work Order : VA22C9812

Client : Vancouver School Board Project : Hastings Elementary



Methodology References and Summaries

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Reference methods may incorporate modifications to improve performance (indicated by "mod").

Analytical Methods	Method / Lab	Matrix	Method Reference	Method Descriptions
Total metals in Water by CRC ICPMS	E420	Water	EPA 200.2/6020B	Water samples are digested with nitric and hydrochloric acids, and analyzed by
			(mod)	Collision/Reaction Cell ICPMS.
	Vancouver -			
	Environmental			Method Limitation (re: Sulfur): Sulfide and volatile sulfur species may not be recovered
				by this method.

ALS Canada Ltd.



QUALITY CONTROL REPORT

Work Order :VA22C9812

Client : Vancouver School Board

: Stephen Thomas Contact Address

: 1549 Clark Drive

Vancouver BC Canada V5L 3L4

Telephone

Project : Hastings Elementary

PO

C-O-C number :20-1039077

Sampler

Site Quote number No. of samples received : 7 No. of samples analysed : 7 Page : 1 of 3

Laboratory : Vancouver - Environmental

Account Manager : Tasnia Tarannum

Address :8081 Lougheed Highway

Burnaby, British Columbia Canada V5A 1W9

Telephone :+1 604 253 4188

Date Samples Received :08-Dec-2022 14:55

Date Analysis Commenced :10-Dec-2022

Issue Date :13-Dec-2022 10:11

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Quality Control Report contains the following information:

Laboratory Duplicate (DUP) Report; Relative Percent Difference (RPD) and Data Quality Objectives

- Matrix Spike (MS) Report; Recovery and Data Quality Objectives
- Method Blank (MB) Report; Recovery and Data Quality Objectives
- Laboratory Control Sample (LCS) Report; Recovery and Data Quality Objectives

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories **Position** Laboratory Department

Kim Jensen Department Manager - Metals Vancouver Metals, Burnaby, British Columbia Page : 2 of 3 Work Order : VA22C9812

Client : Vancouver School Board
Project : Hastings Elementary



General Comments

The ALS Quality Control (QC) report is optionally provided to ALS clients upon request. ALS test methods include comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against predetermined Data Quality Objectives (DQOs) to provide confidence in the accuracy of associated test results. This report contains detailed results for all QC results applicable to this sample submission. Please refer to the ALS Quality Control Interpretation report (QCI) for applicable method references and methodology summaries.

Key:

Anonymous = Refers to samples which are not part of this work order, but which formed part of the QC process lot.

CAS Number = Chemical Abstracts Service number is a unique identifier assigned to discrete substances.

DQO = Data Quality Objective.

LOR = Limit of Reporting (detection limit).

RPD = Relative Percent Difference

= Indicates a QC result that did not meet the ALS DQO.

Workorder Comments

Holding times are displayed as "---" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Laboratory Duplicate (DUP) Report

A Laboratory Duplicate (DUP) is a randomly selected intralaboratory replicate sample. Laboratory Duplicates provide information regarding method precision and sample heterogeneity. ALS DQOs for Laboratory Duplicates are expressed as test-specific limits for Relative Percent Difference (RPD), or as an absolute difference limit of 2 times the LOR for low concentration duplicates within ~ 4-10 times the LOR (cut-off is test-specific).

Sub-Matrix: Water						Laboratory Duplicate (DUP) Report							
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	LOR	Unit	Original Result	Duplicate Result	RPD(%) or Difference	Duplicate Limits	Qualifier		
Total Metals (QC Lo	t: 772887)												
FJ2203376-001	Anonymous	lead, total	7439-92-1	E420	0.000050	mg/L	0.000170	0.000181	0.000011	Diff <2x LOR			

Method Blank (MB) Report

A Method Blank is an analyte-free matrix that undergoes sample processing identical to that carried out for test samples. Method Blank results are used to monitor and control for potential contamination from the laboratory environment and reagents. For most tests, the DQO for Method Blanks is for the result to be < LOR.

Sub-Matrix: Water

Analyte	CAS Number	Method	LOR	Unit	Result	Qualifier
Total Metals (QCLot: 772887)						
lead, total	7439-92-1	E420	0.00005	mg/L	<0.000050	

Page : 3 of 3 Work Order : VA22C9812

Client : Vancouver School Board
Project : Hastings Elementary



Laboratory Control Sample (LCS) Report

A Laboratory Control Sample (LCS) is an analyte-free matrix that has been fortified (spiked) with test analytes at known concentration and processed in an identical manner to test samples. LCS results are expressed as percent recovery, and are used to monitor and control test method accuracy and precision, independent of test sample matrix.

Sub-Matrix: Water	Laboratory Control Sample (LCS) Report								
	Spike	Recovery (%)	Recovery	Limits (%)					
Analyte	CAS Number	Method	LOR	Unit	Concentration	LCS	Low	High	Qualifier
Total Metals (QCLot: 772887)									
lead, total	7439-92-1	E420	0.00005	mg/L	0.5 mg/L	104	80.0	120	

Matrix Spike (MS) Report

A Matrix Spike (MS) is a randomly selected intra-laboratory replicate sample that has been fortified (spiked) with test analytes at known concentration, and processed in an identical manner to test samples. Matrix Spikes provide information regarding analyte recovery and potential matrix effects. MS DQO exceedances due to sample matrix may sometimes be unavoidable; in such cases, test results for the associated sample (or similar samples) may be subject to bias. ND – Recovery not determined, background level >= 1x spike level.

	I V	1 / 2	,	, 3						
Sub-Matrix: Water							ke (MS) Report			
		Spi	ike	Recovery (%)	Recovery	Limits (%)				
Laboratory sample	Client sample ID	Analyte	CAS Number	Method	Concentration	Target	MS	Low	High	Qualifier
Total Metals (QC	CLot: 772887)									
FJ2203376-002	Anonymous	lead, total	7439-92-1	E420	0.0184 mg/L	0.02 mg/L	91.8	70.0	130	



www.alsglobal.com

Canada Toll Free: 1 800 668 9878

coc Number: 20 - 1039077

Page

of

Report To	Contact and company name below will appear on t	the final report		Reports / R	ecipients				Turna	ound Ti	me (TA	T) Requ	ested		178	100	٠	*	Šie .		797
Company:	VANCOUVER SCHOOL B	OARD	Select Report Fo	rmat: 👼 PDF [EXCEL D	D (DIGITAL)	Ø Rou	tine [R]	if received	by 3pm №	1-F - no	surcharg	es apply								Ø.,
Contact:	STEPHEN THOMAS	5	Merge QC/QCl Reports with COA ☐ YES ☐ NO ☐ N/A ☐					4 day [P4] if received by 3pm M-F - 20% rush surcharge minimum AFFIX ALS BARCOD						ARE		_ ·					
Phone:	604-713-5637		Compare Resul	ts to Criteria on Report - p	rovide details below if	box checked	(ALC upo artis)														
	Company address below will appear on the final report	rt S	Select Distributio		MAIL .		2 day [P2] if received by 3pm M-F - 50% rush surcharge minimum 1 day {E} if received by 3pm M-F - 100% rush surcharge minimum								**************************************						
Street:	1549 Clark drive	Į.	Email 1 or Fax		os @ 15b.		Sarr	ne day [E	2] if receive	ed by 10am	n M-S -	200% rus	h surcharge.	Additional	l fees	PH.	K.	W.,			
City/Province:	Vancouver BC			ccarrell 6		(2	1110	y oppony to	/ tubir reque	its on wee	KOILO, S	tatuto y n	olidays and i	non-routine	. 16363	The said	7004		G _{ra}	8,0	緬
Postal Code:			Email 3	V D enoup o				Date and	Time Req							mmn-y			n		
Invoice To	Same as Report To			Învoice Re	 		<u> </u>			For all test	s with ru	sh TATs r	equested, pl			M to confin	n availabil	lity.			
	Copy of Invoice with Report YES 1 No		Select Invoice Di	stribution: 🔲 🖽	IAIL MAIL	FAX	L						Analysi								
Company:			Email 1 or Fax				AINERS	—т	India	ate Filtere	ed (F), F	reserved	(P) or Filter	ed and Pr	reserved ((F/P) below	<u> </u>			Œ	notes)
Contact:		E	Email 2		(=: 1. / // /		┨╬┠	\rightarrow	-			-		\vdash			+	+-		5	Ē
10101	Project Information	<u> </u>		il and Gas Required	,	ie)	₹					ŀ								E C	ee ge
ALS Account # /			AFE/Cost Center:		PO#		ΙΣΙ								1				HOLD	Ä	e l
PO / AFE:	HASTINGS ELEMENTAR		Major/Minor Code:		Routing Code:		CONT					İ	1						エー	\$	🖔
LSD:			Requisitioner: Location:				삥	0											S O	STORAGE REQUIRED	HAZARD (see
		7.9% (7895)		•			1 . I	2	1											S	
ALS Lab Worl	k Order# (ALS use only):	· · · · · · · · · · · · · · · · · · ·	ALS Contact: T	Teranoum	Sampler: K,	nessamore	NUMBER	U)											SAMPLES	EXTENDED	SUSPECTED
ALS Sample # (ALS use only)	Sample Identification and			Date	Time	Sample Type	≩		,			.]							₹	XTE	Si
1,20 000	(This description will appeal	· · · · ·	lier	(dd-mmm-yy)	(hh:mm) 7;20	Mater	-	+	-		1				المستح		_, <u>,</u> _	 	"	ш	"
A 2			1116	8- Dec -22	7:25	water	1	-		1	<u>/</u>	E	nviron	ment	al Di	ivisio	n ¦	+ - 1	\dashv		
	2			8- Dec -22	7:30	Mater	+	_	+	1 1	4	V	ancou	ver	5 .4		F		\neg		
	110 00 117		·	8-Dec - 55	7: 30	Water	1		-	Work Order Reference VA22C9812											
\$175 \ 1813)) 4	SSDF		-				-	_	+	H		VA	22	US	70 1	_				
The same of the sa	COIT 119 RM 112	DF		8-005-55	7:40	water	+		<u> </u>	-	Ц			an - 1	1 1811	e e i	61	 	-		\vdash
100	CONT 022 RM 0	<u> </u>		8-DEC-55	7:45	mater	\sqcup			ļ	4		111/1		441			<u> </u>			
	COXY 022 RM DI	4A DF		8- Dec-22	7:50	water					L			n I	100		\\\\				
**************************************							1 1				Lì -			171	(*7),		111		1		
Dr. 2 18											Γ.		1111	1.0	₩.	94 E	111				
(/94 ₁₂														4 00	4.050.4	100					
The second											Τ.	Т	eleph one	:+160	4 253 4	100					
			• • • • • • • • • • • • • • • • • • • •			· · · · · · ·	\vdash	_		+	<u> </u>		-	1-1		T	\top	1			
i desirior constitution		Notes / Specific	l imits for requit	i evaluation by selecting	s from duon dessur	helour	50 Drag (1988)	Market A		n eresis	⊬SAM	PLE RE	CEIPT D	ETAILS	(ALS	use only	/) ****	265			2
Drinking	Water (DW) Samples¹ (client use)	Notes / Opecity		xcel COC only)	g from drop-down	Delow				.,			☐ ICE PA					OOLING	INITIA	TED	
Are samples taker	from a Regulated DW System?		··········								~	10.5	Receipt] YES _{&}	_			
₩ YE	s 🗀 NO	· N1 -				. 1	Cooler	Custo	dy Seals	Intact:		YES	≅ □ N/A	Samp	le Custo	ody Sea	s Intact	Rossia.	☐ YES	· 🗆	N/A 🍇
Are samples for hi	uman consumption/ use?	No	bu se	ervatives	σαα	lo			ITIAL COO		PERAT			988		NAL COO	LER TEM	PERATU	RES °C		336
YE 图 YE	S 📋 NO						W.						account.	1	66	300		e set			
Boloma	SHIPMENT RELEASE (client use)			INITIAL SHIPMENT		LS use only) 🤲	_	李维。		1000	Law.	FINAL S	SHIPMEN	TREC	PTION	(ALS	se only	/) · · · · · · · · · · · · · · · · · · ·	The second	739	- 18 - 6 - 7 - 1860
Released by:	Date:	100	Received by:		Date:		Time:		Received) inst	Dat	20	² C		<u>{ </u>		1	5	2
	PAGE FOR ALS LOCATIONS AND SAMPLING INFORM portions of this form may delay analysis. Please in in this form		torm the uper acknow		TE - LABORATORY		W - CLIE			d copy.			χ.							AUG 2	220 FRONT

^{1.} Trany water samples are taken from a Regulated Drinking Water (DW) System, please submit using an Authorized DW COC form.

Results Summary VA22C9812

Project Hastings Elementary

Report To Stephen Thomas, Vancouver School Board

 Date Received
 08-Dec-2022 14:55

 Issue Date
 13-Dec-2022 10:12

Amendment 0

Client Sample ID			Corr 121 Rm 136 Bottle Filler	Corr 217 Rm 312 DF	Corr 217 Rm 215 SSDF	Corr 119 Rm 117 SSDF	Corr 119 Rm 112 DF	Corr 022 Rm 018 SSDF	Corr 022 Rm 014A DF
Date Sampled			08-Dec-2022	08-Dec-2022	08-Dec-2022	08-Dec-2022	08-Dec-2022	08-Dec-2022	08-Dec-2022
Time Sampled			07:20	07:25	07:30	07:35	07:40	07:45	07:50
ALS Sample ID			VA22C9812-001	VA22C9812-002	VA22C9812-003	VA22C9812-004	VA22C9812-005	VA22C9812-006	VA22C9812-007
Analyte	Lowest Detection Limit	Units	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water
Total Metals (Matrix: Water)									
lead, total	0.000050	mg/L	0.00226	0.000718	0.000124	0.000121	0.00310	0.000426	0.00170