ALS Canada Ltd.

Contact

Site



CERTIFICATE OF ANALYSIS (GUIDELINE EVALUATION)

: VA23A2832 **Work Order** Page : 1 of 3

Client Laboratory : Vancouver - Environmental : Vancouver School Board

Account Manager : Tasnia Tarannum Address : 1549 Clark Drive Address

: 8081 Lougheed Highway Vancouver BC Canada V5L 3L4

Burnaby, British Columbia Canada V5A 1W9

Telephone Telephone : +1 604 253 4188 : ----Project : Jules Quesnel Elementary **Date Samples Received** : 07-Feb-2023 15:00

Date Analysis Commenced : 09-Feb-2023 PO : 09-Feb-2023 20:59 C-O-C number : 20-1041755 Issue Date

Sampler : RL

: Stephen Thomas

Quote number : Standing Offer

No. of samples received : 5 No. of samples analysed : 5

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

: ----

- General Comments
- Analytical Results
- Guideline Comparison

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories Position Laboratory Department

Robin Weeks Team Leader - Metals Metals, Burnaby, British Columbia Page : 2 of 3 Work Order : VA23A2832

Client : Vancouver School Board
Project : Jules Quesnel Elementary



No Breaches Found

General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information. Guidelines are not adjusted for the hardness, pH or temperature of the sample (the most conservative values are used). Measurement uncertainty is not applied to test results prior to comparison with specified criteria values.

Key: LOR: Limit of Reporting (detection limit).

Unit	Description
mg/L	milligrams per litre

>: greater than.

Red shading is applied where the result is greater than the Guideline Upper Limit or the result is lower than the Guideline Lower Limit.

For drinking water samples, Red shading is applied where the result for E.coli, fecal or total coliforms is greater than or equal to the Guideline Upper Limit.

<: less than.

Page

3 of 3 VA23A2832 Work Order

Client Vancouver School Board Project Jules Quesnel Elementary



Analytical Results Evaluation

Matrix:	Client sample ID									
	Sampling date/time									
		Sub-Matrix								
Analyte	CAS Number	Unit								
		-								
Please refer to the General Comments section for	Please refer to the General Comments section for an explanation of any qualifiers detected.									
Lead, total	7-	439-92-1	mg/L							



QUALITY CONTROL INTERPRETIVE REPORT

Work Order : **VA23A2832** Page : 1 of 5

Client : Vancouver School Board Laboratory : Vancouver - Environmental

Contact : Stephen Thomas Account Manager : Tasnia Tarannum

Address :1549 Clark Drive Address :8081 Lougheed Highway

Burnaby, British Columbia Canada V5A 1W9

Telephone :---- Telephone :+1 604 253 4188

Project :Jules Quesnel Elementary Date Samples Received :07-Feb-2023 15:00

C-O-C number : 20-1041755

Quote number : Standing Offer

:RL

No. of samples received :5
No. of samples analysed :5

This report is automatically generated by the ALS LIMS (Laboratory Information Management System) through evaluation of Quality Control (QC) results and other QA parameters associated with this submission, and is intended to facilitate rapid data validation by auditors or reviewers. The report highlights any exceptions and outliers to ALS Data Quality Objectives, provides holding time details and exceptions, summarizes QC sample frequencies, and lists applicable methodology references and summaries.

Key

Sampler

Site

Anonymous: Refers to samples which are not part of this work order, but which formed part of the QC process lot.

CAS Number: Chemical Abstracts Service number is a unique identifier assigned to discrete substances.

Vancouver BC Canada V5L 3L4

DQO: Data Quality Objective.

LOR: Limit of Reporting (detection limit).

RPD: Relative Percent Difference.

Workorder Comments

Holding times are displayed as "---" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Summary of Outliers

Outliers : Quality Control Samples

- No Method Blank value outliers occur.
- No Duplicate outliers occur.
- No Laboratory Control Sample (LCS) outliers occur
- No Matrix Spike outliers occur.
- No Test sample Surrogate recovery outliers exist.

Outliers: Reference Material (RM) Samples

No Reference Material (RM) Sample outliers occur.

Outliers: Analysis Holding Time Compliance (Breaches) ■ No Analysis Holding Time Outliers exist.

Outliers: Frequency of Quality Control Samples • No Quality Control Sample Frequency Outliers occur.

Page : 3 of 5 Work Order : VA23A2832

Client : Vancouver School Board
Project : Jules Quesnel Elementary



Analysis Holding Time Compliance

This report summarizes extraction / preparation and analysis times and compares each with ALS recommended holding times, which are selected to meet known provincial and/or federal requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by organizations such as CCME, US EPA, APHA Standard Methods, ASTM, or Environment Canada (where available). Dates and holding times reported below represent the first dates of extraction or analysis. If subsequent tests or dilutions exceeded holding times, qualifiers are added (refer to COA).

If samples are identified below as having been analyzed or extracted outside of recommended holding times, measurement uncertainties may be increased, and this should be taken into consideration when interpreting results.

Where actual sampling date is not provided on the chain of custody, the date of receipt with time at 00:00 is used for calculation purposes.

Where only the sample date without time is provided on the chain of custody, the sampling date at 00:00 is used for calculation purposes.

Matrix: Water Evaluation: × = Holding time exceedance; ✓ = Within Holding Time

Matrix: Water					Ev	aluation: × =	Holding time excee	edance ;	✓ = Within	Holding I
Analyte Group	Method	Sampling Date	Ex	traction / Pr	eparation			Analy	sis	
Container / Client Sample ID(s)			Preparation	Holding	g Times	Eval	Analysis Date	Holdin	g Times	Eval
			Date	Rec	Actual			Rec	Actual	
Total Metals : Total metals in Water by CRC ICPMS										
HDPE - total (lab preserved)										
Corr 236 Rm. 232 S.S.D.F.	E420	07-Feb-2023	09-Feb-2023				09-Feb-2023	180	3 days	✓
								days		
Total Metals : Total metals in Water by CRC ICPMS										
HDPE - total (lab preserved)										
Corr. 100 Rm. 136 S.S.D.F.	E420	07-Feb-2023	09-Feb-2023				09-Feb-2023	180	3 days	✓
								days		
Total Metals : Total metals in Water by CRC ICPMS										
HDPE - total (lab preserved)										
Corr. 236 Rm. 231 Bottle Filler	E420	07-Feb-2023	09-Feb-2023				09-Feb-2023	180	3 days	✓
								days		
Fotal Metals : Total metals in Water by CRC ICPMS										
HDPE - total (lab preserved)										
Corr. 310 Rm. 333 S.S.D.F.	E420	07-Feb-2023	09-Feb-2023				09-Feb-2023	180	3 days	✓
								days		
Total Metals : Total metals in Water by CRC ICPMS								,		
HDPE - total (lab preserved)										
Cprr. 100b Rm. 105 S.S.D.F.	E420	07-Feb-2023	09-Feb-2023				09-Feb-2023	180	3 days	1
ори. 1000 кин. 100 о.о.о.т.	L+20	57 1 5B-2020	00-1 00-2020				00-1 00-2020		o days	•
								days		

Legend & Qualifier Definitions

Rec. HT: ALS recommended hold time (see units).

Page : 4 of 5 Work Order : VA23A2832

Client : Vancouver School Board
Project : Jules Quesnel Elementary



Quality Control Parameter Frequency Compliance

The following report summarizes the frequency of laboratory QC samples analyzed within the analytical batches (QC lots) in which the submitted samples were processed. The actual frequency should be greater than or equal to the expected frequency.

Evaluation: × = QC frequency outside specification; ✓ = QC frequency within specific											
Quality Control Sample Type					Frequency (%)						
Analytical Methods	Method	QC Lot #	QC	Regular	Actual	Expected	Evaluation				
Laboratory Duplicates (DUP)											
Total metals in Water by CRC ICPMS	E420	827762	1	17	5.8	5.0	✓				
Laboratory Control Samples (LCS)											
Total metals in Water by CRC ICPMS	E420	827762	1	17	5.8	5.0	✓				
Method Blanks (MB)											
Total metals in Water by CRC ICPMS	E420	827762	1	17	5.8	5.0	✓				
Matrix Spikes (MS)											
Total metals in Water by CRC ICPMS	E420	827762	1	17	5.8	5.0	✓				

Page : 5 of 5 Work Order : VA23A2832

Client : Vancouver School Board
Project : Jules Quesnel Elementary



Methodology References and Summaries

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Reference methods may incorporate modifications to improve performance (indicated by "mod").

Analytical Methods	Method / Lab	Matrix	Method Reference	Method Descriptions
Total metals in Water by CRC ICPMS	E420	Water	EPA 200.2/6020B	Water samples are digested with nitric and hydrochloric acids, and analyzed by
			(mod)	Collision/Reaction Cell ICPMS.
	Vancouver -			
	Environmental			Method Limitation (re: Sulfur): Sulfide and volatile sulfur species may not be recovered
				by this method.

ALS Canada Ltd.



QUALITY CONTROL REPORT

Work Order : VA23A2832

Client : Vancouver School Board

Contact : Stephen Thomas

Address : 1549 Clark Drive

Vancouver BC Canada V5L 3L4

Telephone

Project : Jules Quesnel Elementary

PO :---

C-O-C number : 20-1041755

Sampler : RL

Site :---

Quote number : Standing Offer

No. of samples received : 5
No. of samples analysed : 5

Page : 1 of 3

Laboratory : Vancouver - Environmental

Account Manager : Tasnia Tarannum

Address : 8081 Lougheed Highway

Burnaby, British Columbia Canada V5A 1W9

Telephone : +1 604 253 4188

Date Samples Received : 07-Feb-2023 15:00

Date Analysis Commenced : 09-Feb-2023

Issue Date : 09-Feb-2023 20:59

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Quality Control Report contains the following information:

Laboratory Duplicate (DUP) Report; Relative Percent Difference (RPD) and Data Quality Objectives

- Matrix Spike (MS) Report; Recovery and Data Quality Objectives
- Method Blank (MB) Report; Recovery and Data Quality Objectives
- Laboratory Control Sample (LCS) Report; Recovery and Data Quality Objectives

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories Position Laboratory Department

Robin Weeks Team Leader - Metals Vancouver Metals, Burnaby, British Columbia

Page : 2 of 3 Work Order : VA23A2832

Client : Vancouver School Board
Project : Jules Quesnel Elementary



General Comments

The ALS Quality Control (QC) report is optionally provided to ALS clients upon request. ALS test methods include comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against predetermined Data Quality Objectives (DQOs) to provide confidence in the accuracy of associated test results. This report contains detailed results for all QC results applicable to this sample submission. Please refer to the ALS Quality Control Interpretation report (QCI) for applicable method references and methodology summaries.

Key:

Anonymous = Refers to samples which are not part of this work order, but which formed part of the QC process lot.

CAS Number = Chemical Abstracts Service number is a unique identifier assigned to discrete substances.

DQO = Data Quality Objective.

LOR = Limit of Reporting (detection limit).

RPD = Relative Percent Difference

= Indicates a QC result that did not meet the ALS DQO.

Workorder Comments

Holding times are displayed as "---" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Laboratory Duplicate (DUP) Report

A Laboratory Duplicate (DUP) is a randomly selected intralaboratory replicate sample. Laboratory Duplicates provide information regarding method precision and sample heterogeneity. ALS DQOs for Laboratory Duplicates are expressed as test-specific limits for Relative Percent Difference (RPD), or as an absolute difference limit of 2 times the LOR for low concentration duplicates within ~ 4-10 times the LOR (cut-off is test-specific).

Sub-Matrix: Water				Laboratory Duplicate (DUP) Report							
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	LOR	Unit	Original Result	Duplicate Result	RPD(%) or Difference	Duplicate Limits	Qualifier
Total Metals (QC Lo	t: 827762)										
VA23A2695-012	Anonymous	Lead, total	7439-92-1	E420	0.000050	mg/L	<0.000050	<0.000050	0	Diff <2x LOR	

Method Blank (MB) Report

A Method Blank is an analyte-free matrix that undergoes sample processing identical to that carried out for test samples. Method Blank results are used to monitor and control for potential contamination from the laboratory environment and reagents. For most tests, the DQO for Method Blanks is for the result to be < LOR.

Sub-Matrix: Water

Analyte	CAS Number I	Method	LOR	Unit	Result	Qualifier
Total Metals (QCLot: 827762)						
Lead, total	7439-92-1 E	E420	0.00005	mg/L	<0.000050	

Page : 3 of 3 Work Order : VA23A2832

Client : Vancouver School Board
Project : Jules Quesnel Elementary



Laboratory Control Sample (LCS) Report

A Laboratory Control Sample (LCS) is an analyte-free matrix that has been fortified (spiked) with test analytes at known concentration and processed in an identical manner to test samples. LCS results are expressed as percent recovery, and are used to monitor and control test method accuracy and precision, independent of test sample matrix.

Sub-Matrix: Water					Laboratory Control Sample (LCS) Report					
					Spike	Recovery (%)	Recovery Limits (%)			
Analyte	CAS Number	Method	LOR	Unit	Concentration	LCS	Low	High	Qualifier	
Total Metals (QCLot: 827762)										
Lead, total	7439-92-1	E420	0.00005	mg/L	0.5 mg/L	101	80.0	120		

Matrix Spike (MS) Report

A Matrix Spike (MS) is a randomly selected intra-laboratory replicate sample that has been fortified (spiked) with test analytes at known concentration, and processed in an identical manner to test samples. Matrix Spikes provide information regarding analyte recovery and potential matrix effects. MS DQO exceedances due to sample matrix may sometimes be unavoidable; in such cases, test results for the associated sample (or similar samples) may be subject to bias. ND – Recovery not determined, background level >= 1x spike level.

	1 (1 / 3	,	, 3						
Sub-Matrix: Water					Matrix Spike (MS) Report					
					Spike Recovery (%) Recovery Limits (%)			Limits (%)		
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	Concentration	Target	MS	Low	High	Qualifier
Total Metals (QC	Lot: 827762)									
VA23A2778-001	Anonymous	Lead, total	7439-92-1	E420	0.0187 mg/L	0.02 mg/L	93.4	70.0	130	

Chain of Custody (COC) / Analytical Request Form

coc Number: 20 - 1041

DIST. 101 181

. ' (1)

Canada Toll Free: 1 800 668 9878

www.alsglobai.com

Company: City/Province: Phone: Report To ALS Account # / Quote # invoice To Contact: Company: Released by (ALS use only) ontact: ostal Code: • ALS Sample # ALS Lab Work Order # (ALS use only): samples for human consumption/ use? Ž. ples taken from a Regulated DW System? Drinking Water (DW) Samples' (client K K ON!Y ... SELV. Corr. 236. Copy of Invoice with Report Same as Report To Vencouver wer. 200 15 7 The 15 The Company address below will appear on the final report Quesne Micoures 713-5637 BY THE WAY TO SEE SHIPMENT RELEASE (client use)

Date: Contact and company name below will appear on the final report LA TOTAL CONTRACT 236 310 T. Kr. 8 ノは、大 9001 Project Information 000 School Sample Identification and/or Coordinates (This description will appear on the report) Elementary 3 3 F 73 use) ⊡ Ø Board W W : 105 136 ĕ Ř 4 □ 8 ₹ · 617 4 13 No preservatives added Notes / Specify Limits for result evaluation by selecting from drop-down below (Excel COC only) #12 Time: A to the A bet. 0 0 *** Received by: ALS Contact: 1.- / av a pyrum アジャ Email 2 CLANTEN @ USb. Select Invoice Distribution: Email 1 or Fax 35thanes @ usb. bc. AFE/Cost Center: Email 2 .. Email 1 or Fax Email 3-10 yong @ usb. bc. Select Distribution: ☐ Compare Results to Criteria on Report - provide details below if box checked 🤋 🎨 Select Report Format: Requisitioner: Major/Minor Code: _ocation: (4) ~ [- 1 * 1 * 4 5. Merge QC/QCI Reports with COA 1 Oil and Gas Required Fields (client use) INITIAL SHIPMENT RECEPTION (ALS use on . 17 07.02.23 62 · 20 · FO 07.02.23 07.02.23 07.02.23 (dd-mmm-yy) Reports / Recipients Involce Recipients **전** 공 DAVIT , D WAIT EMAIL. . □ ¥8 Sampler □ MAI PO# : Routing Code: pc ca 7:3/6-EXCE 4. .4. Hlam (hh:mm) 1 7 4 分の情報 ような ž EDD (DIGITAL) FAX • 🛠 in the way to 8 N/A water Covar. FAX estate C water Sample Type . 111 なか Ę. 3 Routine [R] if received by 3pm M-F - no surcharges apply

4 day [P4] if received by 3pm. M-F - 20% rush surcharge minimum

3 day [P3] if received by 3pm M-F - 25% rush surcharge minimum

2 day [P3] if received by 3pm M-F - 50% rush surcharge minimum

1 day [P3] if received by 3pm M-F - 100% rush surcharge minimum

1 day [E] if received by 3pm M-F - 100% rush surcharge minimum Same day [22] if received by 10am M-S - 200% rush surcharge, Additional fees may apply to rush requests on weekends, statutory holidays and non-routine tests Time: Submission Comments identified on Sample Receipt Notification: Cooling Method: NUMBER OF CONTAINERS Lead ੂੰ ਮੂੰ ਤੂੰ Received by: Turnaround Time (TAT) Requested * Indicate Filtered (F), Preserved (P) or Filtered and Preserved (F/P) below ō □ ®NONE ® □ For all tests with rush TATs requested, please contact your AM to confirm availability. 1.5 R į 6 FINAL SHIPMENT RECEPTION (ALS ☐ YES ※ ☐ N/A ICE TO ICE PACKS TO ROZEN **Environmental Division** Telephone: +1 604 253 4188 ن ا الم Analysis Request Sample Custody Seals Intact: dd-mmm-yy hh:m<u>m</u> am/pm AFFIX ALS BARCODE LABEL HERE ... (ALS use only) 100 Ş ☐ YES » ☐ NVA SAMPLES ON HOLD رز برز <u>د</u> Ê ij EXTENDED STORAGE REQUIRED 3 SUSPECTED HAZARD (see notes

REFER TO BACK PAGE FOR ALS LOCATIONS AND SAMPLING INFORMATION

1. If any water samples are taken from a Regulated Drinking Water (DW) System, Fallure to complete all portions of this form may delay analysis. Please fill in this form LEGIBLY. By the use of this form the user ecknowledges and egrees with the Terms and Conditions as specified on the backage of the white report copy. please submit using an Authorized DW COC form

YELLOW - CLIENT COP

Results Summary VA23A2832

Project Jules Quesnel Elementary

Report To Stephen Thomas, Vancouver School Board

 Date Received
 07-Feb-2023 15:00

 Issue Date
 09-Feb-2023 20:59

Amendment

Client Sample ID			S.S.D.F.	S.S.D.F.	S.S.D.F.	S.S.D.F.	Bottle Filler
Date Sampled			07-Feb-2023	07-Feb-2023	07-Feb-2023	07-Feb-2023	07-Feb-2023
Time Sampled			07:31	07:35	07:41	07:45	07:56
ALS Sample ID			VA23A2832-001	VA23A2832-002	VA23A2832-003	VA23A2832-004	VA23A2832-005
Analyte	Lowest Detection Limit	Units	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water
Total Metals (Matrix: Water)							
Lead, total	0.000050	mg/L	0.000090	0.000121	0.000103	0.000082	<0.000050