

Results Summary VA23C5354

Project DR A.R. Lord Elementary
Report To Stephen Thomas, Vancouver School Board
Date Received 23-Oct-2023 14:55
Issue Date 31-Oct-2023 20:35
Amendment 0

Client Sample ID			Building 61B Corr. 200 Rm. 208 Bottle Filler	Building 61B Corr. 104 SSDF	Building 61B Corr.104 Rm. 109 FGDF	Building 61A Corr. 100 SSDF
Date Sampled			23-Oct-2023	23-Oct-2023	23-Oct-2023	23-Oct-2023
Time Sampled			07:21	07:24	07:27	07:46
ALS Sample ID			VA23C5354-001	VA23C5354-002	VA23C5354-003	VA23C5354-004
Analyte	Lowest Detection Limit	Units	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water
Total Metals (Matrix: Water)						
Lead, total	0.000050	mg/L	0.00101	0.00162	0.000829	0.00536