

Results Summary VA23C6320

Project Mount Pleasant Elementary
Report To Stephen Thomas, Vancouver School Board
Date Received 01-Nov-2023 14:45
Issue Date 07-Nov-2023 10:04
Amendment 0

| Client Sample ID | | | Hallway outside Rn.218 SSDF | Beside Rn.126 Bottle Filler | Beside Rn.127 D.F. | Girls change Rn.133 D.F. |
|-------------------------------------|---------------------------|-------|--------------------------------|--------------------------------|-------------------------------|-------------------------------|
| Date Sampled | | | 01-Nov-2023 | 01-Nov-2023 | 01-Nov-2023 | 01-Nov-2023 |
| Time Sampled | | | 08:01 | 08:04 | 08:06 | 08:09 |
| ALS Sample ID | | | VA23C6320-001 | VA23C6320-002 | VA23C6320-003 | VA23C6320-004 |
| Analyte | Lowest Detection Limit | Units | Sub-Matrix: Drinking Water | Sub-Matrix: Drinking Water | Sub-Matrix: Drinking Water | Sub-Matrix: Drinking Water |
| Total Metals (Matrix: Water) | | | | | | |
| Lead, total | 0.000050 | mg/L | 0.00201 | 0.000068 | 0.000830 | 0.00228 |