



VANCOUVER SCHOOL BOARD  
ATTN: Facilities  
Maintenance and Construction  
1549 Clark Drive  
Vancouver BC V5L 3L4

Date Received: 31-MAY-16  
Report Date: 07-JUN-16 17:39 (MT)  
Version: FINAL

Client Phone: --

## Certificate of Analysis

**Lab Work Order #:** L1776244  
**Project P.O. #:** 0000125902  
**Job Reference:**  
**C of C Numbers:** 10-379653, 14-496984, 14-496985  
**Legal Site Desc:**

**Comments:** Reporting each school separately.

Dean Watt, B.Sc.  
Account Manager

[This report shall not be reproduced except in full without the written authority of the Laboratory.]

ADDRESS: 8081 Lougheed Hwy, Suite 100, Burnaby, BC V5A 1W9 Canada | Phone: +1 604 253 4188 | Fax: +1 604 253 6700  
ALS CANADA LTD Part of the ALS Group A Campbell Brothers Limited Company

# ALS ENVIRONMENTAL ANALYTICAL REPORT

	<b>Sample ID</b> <b>Description</b> <b>Sampled Date</b> <b>Sampled Time</b> <b>Client ID</b>	L1776244-6 WATER 31-MAY-16 10:00 MOUNT PLEASANT 126-DF	L1776244-7 WATER 31-MAY-16 10:00 MOUNT PLEASANT 139-SINK	L1776244-8 WATER 31-MAY-16 10:10 MOUNT PLEASANT 221-DF		
Grouping	Analyte					
<b>WATER</b>						
<b>Total Metals</b>	Lead (Pb)-Total (mg/L)	0.00900	0.0135	0.00144		