



Date: 04-JUN-19

PO No.: 1517879

WO No.: L2282548

LSD:

Project Ref: MOUNT PLEASANT ELEMENTARY

Sample ID: RM 135

Sampled By: Chris Carrell

Date Collected: 30-MAY-19

Lab Sample ID: L2282548-1

Matrix: water

VANCOUVER SCHOOL BOARD  
Maintenance and Construction  
1549 Clark Drive  
Vancouver BC V5L 3L4  
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
<b>Total Metals</b> Lead (Pb)-Total	0.000158		mg/L	0.005		31-MAY-19
<p><b>CDWQG = Health Canada Guideline Limits updated MAY 2018</b></p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L &lt; or N.D. = less than detection limit.            * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality            - A blank entry designates no known limit.            - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by             _____            Joanne Lee            Account Manager</p>						



Date: 04-JUN-19

PO No.: 1517879

WO No.: L2282548

LSD:

Project Ref: MOUNT PLEASANT ELEMENTARY

Sample ID: RM 219

Sampled By: Chris Carrell

Date Collected: 30-MAY-19

Lab Sample ID: L2282548-2

Matrix: water

**VANCOUVER SCHOOL BOARD**  
**Maintenance and Construction**  
 1549 Clark Drive  
 Vancouver BC V5L 3L4  
 ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
<b>Total Metals</b> Lead (Pb)-Total	0.00161		mg/L	0.005		31-MAY-19
<p><b>CDWQG = Health Canada Guideline Limits updated MAY 2018</b></p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L &lt; or N.D. = less than detection limit.            * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality            - A blank entry designates no known limit.            - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by             _____            Joanne Lee            Account Manager</p>						



Date: 04-JUN-19

PO No.: 1517879

WO No.: L2282548

LSD:

Project Ref: MOUNT PLEASANT ELEMENTARY

Sample ID: RM 221

Sampled By: Chris Carrell

Date Collected: 30-MAY-19

Lab Sample ID: L2282548-3

Matrix: water

VANCOUVER SCHOOL BOARD  
Maintenance and Construction  
1549 Clark Drive  
Vancouver BC V5L 3L4  
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
<b>Total Metals</b> Lead (Pb)-Total	0.000464		mg/L	0.005		31-MAY-19
<p><b>CDWQG = Health Canada Guideline Limits updated MAY 2018</b></p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L &lt; or N.D. = less than detection limit.            * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality            - A blank entry designates no known limit.            - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by             _____            Joanne Lee            Account Manager</p>						



Date: 04-JUN-19

PO No.: 1517879

WO No.: L2282548

LSD:

Project Ref: MOUNT PLEASANT ELEMENTARY

Sample ID: RM 133

Sampled By: Chris Carrell

Date Collected: 30-MAY-19

Lab Sample ID: L2282548-4

Matrix: water

VANCOUVER SCHOOL BOARD  
Maintenance and Construction  
1549 Clark Drive  
Vancouver BC V5L 3L4  
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
<b>Total Metals</b> Lead (Pb)-Total	0.000557		mg/L	0.005		31-MAY-19
<p><b>CDWQG = Health Canada Guideline Limits updated MAY 2018</b></p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L &lt; or N.D. = less than detection limit.            * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality            - A blank entry designates no known limit.            - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by             _____            Joanne Lee            Account Manager</p>						



Date: 04-JUN-19

PO No.: 1517879

WO No.: L2282548

LSD:

Project Ref: MOUNT PLEASANT ELEMENTARY

Sample ID: RM 123

Sampled By: Chris Carrell

Date Collected: 30-MAY-19

Lab Sample ID: L2282548-5

Matrix: water

**VANCOUVER SCHOOL BOARD**  
**Maintenance and Construction**  
 1549 Clark Drive  
 Vancouver BC V5L 3L4  
 ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
<b>Total Metals</b> Lead (Pb)-Total	0.00114		mg/L	0.005		31-MAY-19
<p><b>CDWQG = Health Canada Guideline Limits updated MAY 2018</b></p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L &lt; or N.D. = less than detection limit.            * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality            - A blank entry designates no known limit.            - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by             _____            Joanne Lee            Account Manager</p>						

## Guidelines & Objectives

### Health Canada MAC Health Related Criteria Limits

Nitrate/Nitrite-N*	Criteria limit is 10 mg/L (1.0 mg/L if present as all Nitrite-N). High concentrations may contribute to blue baby syndrome in infants.
Lead*	A cumulative body poison, uncommon in naturally occurring hard waters.
Fluoride*	Present in fluoridated water supplies at 0.8 mg/L to reduce dental caries. Elevated levels causes fluorosis (mottling of teeth).
Total Coliforms*	Criteria is 0 CFU/100mL. Adverse health effects.
E. Coli*	Criteria is 0 CFU/100 mL. Certain E. Coli bacteria can be life threatening.

\*Health Canada Canadian Drinking Water Quality Guidelines (MAC limit)

### Aesthetic Objective Concentration Levels

Alkalinity	Acid neutralizing capacity. Usually a measure of carbonate and bicarbonates and calculated and reported as calcium carbonate.
Balance	Quality control parameter ratioing cations to anions
Bicarbonate	See Alkalinity. Report as the anion HCO <sub>3</sub> -1
Carbonate	See Alkalinity. Reported at the anion CO <sub>3</sub> -2
Calcium	See Hardness. Common major cation of water chemistry.
Chloride	Common major anion of water chemistry.
Conductance	Physical test measuring water salinity (dissolved ions or solids)
Hardness	Classical measure or capacity of water to precipitate soap (chiefly calcium and magnesium ions). Causes scaling tendency in water if carbonates/bicarbonates are present (if >200 mg/L). For drinking water purposes waters with results <200 mg/L are considered acceptable, results >200 mg/L are considered poor but can be tolerated. Results >500 mg/L are unacceptable.
Hydroxide	See alkalinity
Magnesium	See hardness. Common major cation of water chemistry. Elevated levels (>125 mg/L) may exert a cathartic or diuretic action.
pH	Measure of water acidity/alkalinity. Normal range is 7.0-8.5.
Potassium	Common major cation of water chemistry.
Sodium	Common major cation of water chemistry. Measure of salinity (saltiness).
Sulphate	Common major anion of water chemistry. Elevated levels may exert a cathartic or diuretic action.
Total Dissolved Solids	A measure of water salinity.
Iron	Causes staining to laundry and porcelain and astringent taste. Oxidizes to red-brown precipitate on exposure to air.
Manganese	Elevated levels may cause staining of laundry and porcelain.
Heterotrophic Plate Count	Criteria is 500 cfu/mL Measure of heterotrophic bacteria present.

### GLOSSARY OF REPORT TERMS

*Surrogates are compounds that are similar in behaviour to target analyte(s), but that do not normally occur in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery. In reports that display the D.L. column, laboratory objectives for surrogates are listed there.*

*mg/kg - milligrams per kilogram based on dry weight of sample*

*mg/kg wwt - milligrams per kilogram based on wet weight of sample*

*mg/kg lwt - milligrams per kilogram based on lipid-adjusted weight*

*mg/L - unit of concentration based on volume, parts per million.*

*< - Less than.*

*D.L. - The reporting limit.*

*N/A - Result not available. Refer to qualifier code and definition for explanation.*

*Test results reported relate only to the samples as received by the laboratory.*

*UNLESS OTHERWISE STATED, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.*

*Analytical results in unsigned test reports with the DRAFT watermark are subject to change, pending final QC review.*



Chain of Custody (COC) / Analytical Request Form

Canada Toll Free: 1 800 668 9878



L2282548-COFC

COC Number: 17 - 765040

Page of

www.alsglobal.com

<b>Report To</b> Contact and company name below will appear on the final report		<b>Report Format / Distribution</b>			<b>Select Service Level Below - Contact your AM to confirm all E&amp;P TATs (surcharges may apply)</b>																																																																																																					
Company: Vancouver School Board		Select Report Format: <input checked="" type="checkbox"/> PDF <input type="checkbox"/> EXCEL <input type="checkbox"/> EDD (DIGITAL)			Regular [R] <input checked="" type="checkbox"/> Standard TAT if received by 3 pm - business days - no surcharges apply																																																																																																					
Contact: Stephen Thomas		Quality Control (QC) Report with Report <input type="checkbox"/> YES <input type="checkbox"/> NO			Priority (Business Days)		EMERGENCY																																																																																																			
Phone: 604-713-5637		<input type="checkbox"/> Compare Results to Criteria on Report - provide details below if box checked			4 day [P4-20%] <input type="checkbox"/>		1 Business day [E - 100%] <input type="checkbox"/>																																																																																																			
Company address below will appear on the final report		Select Distribution: <input checked="" type="checkbox"/> EMAIL <input type="checkbox"/> MAIL <input type="checkbox"/> FAX			3 day [P3-25%] <input type="checkbox"/>		Same Day, Weekend or Statutory holiday [E2 -200% (Laboratory opening fees may apply)] <input type="checkbox"/>																																																																																																			
Street: 1549 Clark Dr.		Email 1 or Fax: SSThomas@vsb.bc.ca			Date and Time Required for all E&P TATs: dd-mmm-yy hh:mm																																																																																																					
City/Province: Vancouver / BC		Email 2			For tests that can not be performed according to the service level selected, you will be contacted.																																																																																																					
Postal Code:		Email 3			<b>Analysis Request</b>																																																																																																					
<b>Invoice To</b>		<b>Invoice Distribution</b>			<table border="1"> <tr> <td colspan="12">Indicate Filtered (F), Preserved (P) or Filtered and Preserved (FP) below</td> </tr> <tr> <td rowspan="6" style="writing-mode: vertical-rl; transform: rotate(180deg);">NUMBER OF CONTAINERS</td> <td rowspan="6" style="writing-mode: vertical-rl; transform: rotate(180deg);">LEAD</td> <td colspan="10"></td> </tr> <tr><td colspan="10"></td></tr> <tr><td colspan="10"></td></tr> <tr><td colspan="10"></td></tr> <tr><td colspan="10"></td></tr> <tr><td colspan="10"></td></tr> <tr> <td colspan="12" style="writing-mode: vertical-rl; transform: rotate(180deg);">SAMPLES ON HOLD</td> </tr> <tr> <td colspan="12" style="writing-mode: vertical-rl; transform: rotate(180deg);">SUSPECTED HAZARD (see Special Instructions)</td> </tr> </table>				Indicate Filtered (F), Preserved (P) or Filtered and Preserved (FP) below												NUMBER OF CONTAINERS	LEAD																																																													SAMPLES ON HOLD												SUSPECTED HAZARD (see Special Instructions)											
Indicate Filtered (F), Preserved (P) or Filtered and Preserved (FP) below																																																																																																										
NUMBER OF CONTAINERS	LEAD																																																																																																									
SAMPLES ON HOLD																																																																																																										
SUSPECTED HAZARD (see Special Instructions)																																																																																																										
Same as Report To <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		Select Invoice Distribution: <input checked="" type="checkbox"/> EMAIL <input type="checkbox"/> MAIL <input type="checkbox"/> FAX																																																																																																								
Copy of Invoice with Report <input type="checkbox"/> YES <input type="checkbox"/> NO		Email 1 or Fax: SSThomas@vsb.bc.ca																																																																																																								
Company:		Email 2																																																																																																								
Contact:																																																																																																										
<b>Project Information</b>		<b>Oil and Gas Required Fields (client use)</b>																																																																																																								
ALS Account # / Quote #:		AFE/Cost Center: PO#																																																																																																								
Job #: Mount Pleasant Elementary		Major/Minor Code: Routing Code:																																																																																																								
PO / AFE:		Requisitioner:																																																																																																								
LSD:		Location:																																																																																																								
ALS Lab Work Order # (lab use only):		ALS Contact:		Sampler: Chris Carrell																																																																																																						
ALS Sample # (lab use only)	Sample Identification and/or Coordinates (This description will appear on the report)	Date (dd-mmm-yy)	Time (hh:mm)	Sample Type																																																																																																						
	RM 135	30-May-19	07:19	water																																																																																																						
	RM 219	30-May-19	08:15	water																																																																																																						
	RM 221	30-May-19	08:18	water																																																																																																						
	RM 133	30-May-19	08:25	water																																																																																																						
	RM 123	30-May-19	08:28	water																																																																																																						
<b>Drinking Water (DW) Samples' (client use)</b>		<b>Special Instructions / Specify Criteria to add on report by clicking on the drop-down list below (electronic COC only)</b>			<b>SAMPLE CONDITION AS RECEIVED (lab use only)</b>																																																																																																					
Are samples taken from a Regulated DW System? <input type="checkbox"/> YES <input type="checkbox"/> NO		No preservatives added			Frozen <input type="checkbox"/> SIF Observations Yes <input type="checkbox"/> No <input type="checkbox"/>																																																																																																					
Are samples for human consumption/ use? <input type="checkbox"/> YES <input type="checkbox"/> NO					Ice Packs <input checked="" type="checkbox"/> Ice Cubes <input type="checkbox"/> Custody seal intact Yes <input type="checkbox"/> No <input type="checkbox"/>																																																																																																					
					Cooling Initiated <input checked="" type="checkbox"/>																																																																																																					
					INITIAL COOLER TEMPERATURES °C																																																																																																					
					FINAL COOLER TEMPERATURES °C																																																																																																					
					K																																																																																																					
<b>SHIPMENT RELEASE (client use)</b>			<b>INITIAL SHIPMENT RECEPTION (lab use only)</b>			<b>FINAL SHIPMENT RECEPTION (lab use only)</b>																																																																																																				
Released by:	Date:	Time:	Received by:	Date:	Time:	Received by: HA	Date: 5/30	Time: 2:30p																																																																																																		

REFER TO BACK PAGE FOR ALS LOCATIONS AND SAMPLING INFORMATION

WHITE - LABORATORY COPY YELLOW - CLIENT COPY

JUNE 2018 FRONT

1. If any water samples are taken from a Regulated Drinking Water (DW) System, please submit using an Authorized DW COC form.