ALS Canada Ltd.

Contact



CERTIFICATE OF ANALYSIS (GUIDELINE EVALUATION)

Account Manager

VA22D0685 Work Order Page : 1 of 3

Client Laboratory : Vancouver - Environmental : Vancouver School Board

Address : 1549 Clark Drive Address : 8081 Lougheed Highway

Vancouver BC Canada V5L 3L4

Burnaby, British Columbia Canada V5A 1W9

: Tasnia Tarannum

Telephone Telephone : +1 604 253 4188 : ----Project : Mount Pleasant Elementary **Date Samples Received** : 19-Dec-2022 15:30 **Date Analysis Commenced** : 22-Dec-2022 PO

: 28-Dec-2022 16:34 C-O-C number : 20-1038009 Issue Date Sampler : RL

Site : ----Quote number No. of samples received : 5 No. of samples analysed : 5

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

: Stephen Thomas

- General Comments
- Analytical Results
- Guideline Comparison

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories Laboratory Department Position

Kevin Duarte Supervisor - Metals ICP Instrumentation Metals, Burnaby, British Columbia Page : 2 of 3 Work Order · VA22D0685

Client : Vancouver School Board
Project : Mount Pleasant Elementary



No Breaches Found

General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information. Guidelines are not adjusted for the hardness, pH or temperature of the sample (the most conservative values are used). Measurement uncertainty is not applied to test results prior to comparison with specified criteria values.

Key: LOR: Limit of Reporting (detection limit).

Unit	Description
mg/L	milligrams per litre

>: greater than.

Red shading is applied where the result is greater than the Guideline Upper Limit or the result is lower than the Guideline Lower Limit.

For drinking water samples, Red shading is applied where the result for E.coli, fecal or total coliforms is greater than or equal to the Guideline Upper Limit.

<: less than.

Page

3 of 3 VA22D0685 Work Order

Client Vancouver School Board Mount Pleasant Elementary Project



Analytical Results Evaluation

Matrix:	Client sample I									
	Sampling date/time									
		Sub-Matrix								
Analyte	CAS Number	Unit								
		-								
Please refer to the General Comments section	Please refer to the General Comments section for an explanation of any qualifiers detected.									
lead, total	74	139-92-1	mg/L							



QUALITY CONTROL INTERPRETIVE REPORT

Work Order : **VA22D0685** Page : 1 of 5

Client : Vancouver School Board Laboratory : Vancouver - Environmental

Contact : Stephen Thomas Account Manager : Tasnia Tarannum

Address :1549 Clark Drive Address :8081 Lougheed Highway

Vancouver BC Canada V5L 3L4

Burnaby, British Columbia Canada V5A 1W9

Telephone :--- Telephone :+1 604 253 4188

Project : Mount Pleasant Elementary Date Samples Received : 19-Dec-2022 15:30
PO : ---- Issue Date : 28-Dec-2022 16:35

PO : ---- Issue Date : 28-Dec-2022 16:35 C-O-C number : 20-1038009

Sampler : RL Site :---

Quote number :--No. of samples received :5
No. of samples analysed :5

This report is automatically generated by the ALS LIMS (Laboratory Information Management System) through evaluation of Quality Control (QC) results and other QA parameters associated with this submission, and is intended to facilitate rapid data validation by auditors or reviewers. The report highlights any exceptions and outliers to ALS Data Quality Objectives, provides holding time details and exceptions, summarizes QC sample frequencies, and lists applicable methodology references and summaries.

Key

Anonymous: Refers to samples which are not part of this work order, but which formed part of the QC process lot.

CAS Number: Chemical Abstracts Service number is a unique identifier assigned to discrete substances.

DQO: Data Quality Objective.

LOR: Limit of Reporting (detection limit).

RPD: Relative Percent Difference.

Workorder Comments

Holding times are displayed as "---" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Summary of Outliers

Outliers : Quality Control Samples

- No Method Blank value outliers occur.
- No Duplicate outliers occur.
- No Laboratory Control Sample (LCS) outliers occur
- No Matrix Spike outliers occur.
- No Test sample Surrogate recovery outliers exist.

Outliers: Reference Material (RM) Samples

No Reference Material (RM) Sample outliers occur.

Outliers: Analysis Holding Time Compliance (Breaches) ■ No Analysis Holding Time Outliers exist.

Outliers: Frequency of Quality Control Samples • No Quality Control Sample Frequency Outliers occur.

Page : 3 of 5 Work Order : VA22D0685

Client : Vancouver School Board
Project : Mount Pleasant Elementary



Analysis Holding Time Compliance

This report summarizes extraction / preparation and analysis times and compares each with ALS recommended holding times, which are selected to meet known provincial and/or federal requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by organizations such as CCME, US EPA, APHA Standard Methods, ASTM, or Environment Canada (where available). Dates and holding times reported below represent the first dates of extraction or analysis. If subsequent tests or dilutions exceeded holding times, qualifiers are added (refer to COA).

If samples are identified below as having been analyzed or extracted outside of recommended holding times, measurement uncertainties may be increased, and this should be taken into consideration when interpreting results.

Where actual sampling date is not provided on the chain of custody, the date of receipt with time at 00:00 is used for calculation purposes.

Where only the sample date without time is provided on the chain of custody, the sampling date at 00:00 is used for calculation purposes.

Matrix: Water Fyaluation: ★ = Holding time exceedance: ✓ = Within Holding Time

Matrix: Water					EV	aluation: 🔻 =	Holding time excee	edance ;	▼ = vvitnin	Holding 11
Analyte Group	Method	Sampling Date	Ex	traction / Pr	eparation			Analy	sis	
Container / Client Sample ID(s)			Preparation	Holding	g Times	Eval	Analysis Date	Holdin	g Times	Eval
			Date	Rec	Actual			Rec	Actual	
Total Metals : Total metals in Water by CRC ICPMS										
HDPE - total (lab preserved)										
Boys change room 123 DF	E420	19-Dec-2022	22-Dec-2022				23-Dec-2022	180	4 days	✓
								days		
Total Metals : Total metals in Water by CRC ICPMS										
HDPE - total (lab preserved)										
Corr 100 RM 126 Bottle Filter	E420	19-Dec-2022	22-Dec-2022				23-Dec-2022	180	4 days	✓
								days		
Total Metals : Total metals in Water by CRC ICPMS										
HDPE - total (lab preserved)										
Corr 100 RM 127 DF	E420	19-Dec-2022	22-Dec-2022				23-Dec-2022	180	4 days	✓
								days		
Total Metals : Total metals in Water by CRC ICPMS										
HDPE - total (lab preserved)										
Corr 200 RM 218 SSDF	E420	19-Dec-2022	22-Dec-2022				23-Dec-2022	180	4 days	✓
								days		
Total Metals : Total metals in Water by CRC ICPMS										
HDPE - total (lab preserved)										
Girls Change room 133 DF	E420	19-Dec-2022	22-Dec-2022				23-Dec-2022	180	4 days	✓
•								days		

Legend & Qualifier Definitions

Rec. HT: ALS recommended hold time (see units).

Page : 4 of 5 Work Order : VA22D0685

Client : Vancouver School Board
Project : Mount Pleasant Elementary



Quality Control Parameter Frequency Compliance

The following report summarizes the frequency of laboratory QC samples analyzed within the analytical batches (QC lots) in which the submitted samples were processed. The actual frequency should be greater than or equal to the expected frequency.

Matrix: Water	Evaluation: × = QC frequency outside specification, ✓ = QC frequency within specific									
Quality Control Sample Type					Frequency (%)					
Analytical Methods	Method	QC Lot #	QC	Regular	Actual	Expected	Evaluation			
Laboratory Duplicates (DUP)										
Total metals in Water by CRC ICPMS	E420	786100	1	16	6.2	5.0	✓			
Laboratory Control Samples (LCS)										
Total metals in Water by CRC ICPMS	E420	786100	1	16	6.2	5.0	✓			
Method Blanks (MB)										
Total metals in Water by CRC ICPMS	E420	786100	1	16	6.2	5.0	✓			
Matrix Spikes (MS)										
Total metals in Water by CRC ICPMS	E420	786100	1	16	6.2	5.0	✓			

Page : 5 of 5 Work Order : VA22D0685

Client : Vancouver School Board
Project : Mount Pleasant Elementary



Methodology References and Summaries

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Reference methods may incorporate modifications to improve performance (indicated by "mod").

Analytical Methods	Method / Lab	Matrix	Method Reference	Method Descriptions
Total metals in Water by CRC ICPMS	E420	Water	EPA 200.2/6020B	Water samples are digested with nitric and hydrochloric acids, and analyzed by
			(mod)	Collision/Reaction Cell ICPMS.
	Vancouver -			
	Environmental			Method Limitation (re: Sulfur): Sulfide and volatile sulfur species may not be recovered
				by this method.

ALS Canada Ltd.



QUALITY CONTROL REPORT

Work Order :VA22D0685

Client : Vancouver School Board

: Stephen Thomas Address : 1549 Clark Drive

Vancouver BC Canada V5L 3L4

Telephone

Contact

Project : Mount Pleasant Elementary

PO

C-O-C number :20-1038009

Sampler :RL

Site Quote number No. of samples received : 5 No. of samples analysed : 5 Page : 1 of 3

Laboratory : Vancouver - Environmental

Account Manager : Tasnia Tarannum

Address :8081 Lougheed Highway

Burnaby, British Columbia Canada V5A 1W9

Telephone :+1 604 253 4188

Date Samples Received :19-Dec-2022 15:30

Date Analysis Commenced : 22-Dec-2022

Issue Date :28-Dec-2022 16:34

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Quality Control Report contains the following information:

Laboratory Duplicate (DUP) Report; Relative Percent Difference (RPD) and Data Quality Objectives

- Matrix Spike (MS) Report; Recovery and Data Quality Objectives
- Method Blank (MB) Report; Recovery and Data Quality Objectives
- Laboratory Control Sample (LCS) Report; Recovery and Data Quality Objectives

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories **Position** Laboratory Department

Kevin Duarte Supervisor - Metals ICP Instrumentation Vancouver Metals, Burnaby, British Columbia

Page : 2 of 3 Work Order : VA22D0685

Client : Vancouver School Board
Project : Mount Pleasant Elementary



General Comments

The ALS Quality Control (QC) report is optionally provided to ALS clients upon request. ALS test methods include comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against predetermined Data Quality Objectives (DQOs) to provide confidence in the accuracy of associated test results. This report contains detailed results for all QC results applicable to this sample submission. Please refer to the ALS Quality Control Interpretation report (QCI) for applicable method references and methodology summaries.

Key:

Anonymous = Refers to samples which are not part of this work order, but which formed part of the QC process lot.

CAS Number = Chemical Abstracts Service number is a unique identifier assigned to discrete substances.

DQO = Data Quality Objective.

LOR = Limit of Reporting (detection limit).

RPD = Relative Percent Difference

= Indicates a QC result that did not meet the ALS DQO.

Workorder Comments

Holding times are displayed as "---" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Laboratory Duplicate (DUP) Report

A Laboratory Duplicate (DUP) is a randomly selected intralaboratory replicate sample. Laboratory Duplicates provide information regarding method precision and sample heterogeneity. ALS DQOs for Laboratory Duplicates are expressed as test-specific limits for Relative Percent Difference (RPD), or as an absolute difference limit of 2 times the LOR for low concentration duplicates within ~ 4-10 times the LOR (cut-off is test-specific).

Sub-Matrix: Water				Laboratory Duplicate (DUP) Report							
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	LOR	Unit	Original Result	Duplicate Result	RPD(%) or Difference	Duplicate Limits	Qualifier
Total Metals (QC Lo	t: 786100)										
KS2204585-002	Anonymous	lead, total	7439-92-1	E420	0.000100	mg/L	0.00180	0.00184	2.18%	20%	

Method Blank (MB) Report

A Method Blank is an analyte-free matrix that undergoes sample processing identical to that carried out for test samples. Method Blank results are used to monitor and control for potential contamination from the laboratory environment and reagents. For most tests, the DQO for Method Blanks is for the result to be < LOR.

Sub-Matrix: Water

Analyte	CAS Number	Method	LOR	Unit	Result	Qualifier
Total Metals (QCLot: 786100)						
lead, total	7439-92-1	E420	0.00005	mg/L	<0.000050	

Page: 3 of 3

Work Order: VA22D0685

Client : Vancouver School Board
Project : Mount Pleasant Elementary



Laboratory Control Sample (LCS) Report

A Laboratory Control Sample (LCS) is an analyte-free matrix that has been fortified (spiked) with test analytes at known concentration and processed in an identical manner to test samples. LCS results are expressed as percent recovery, and are used to monitor and control test method accuracy and precision, independent of test sample matrix.

Sub-Matrix: Water					Laboratory Control Sample (LCS) Report				
				Spike	Recovery (%)	ry (%) Recovery Limits (%)			
Analyte	CAS Number	Method	LOR	Unit	Concentration	LCS	Low	High	Qualifier
Total Metals (QCLot: 786100)									
lead, total	7439-92-1	E420	0.00005	mg/L	0.5 mg/L	95.0	80.0	120	

Matrix Spike (MS) Report

A Matrix Spike (MS) is a randomly selected intra-laboratory replicate sample that has been fortified (spiked) with test analytes at known concentration, and processed in an identical manner to test samples. Matrix Spikes provide information regarding analyte recovery and potential matrix effects. MS DQO exceedances due to sample matrix may sometimes be unavoidable; in such cases, test results for the associated sample (or similar samples) may be subject to bias. ND – Recovery not determined, background level >= 1x spike level.

	1 (1 / 3	,	, 3						
Sub-Matrix: Water					Matrix Spike (MS) Report				•	
					Sp	ike	Recovery (%)	Recovery	Limits (%)	
Laboratory sample ID	Client sample ID	Analyte	CAS Number	Method	Concentration	Target	MS	Low	High	Qualifier
Total Metals (QC	Total Metals (QCLot: 786100)									
KS2204585-003	Anonymous	lead, total	7439-92-1	E420	19.2 mg/L	20 mg/L	96.0	70.0	130	

Chain of Custody (COC) / Analytical Request Form

coc Number: 20 - 1038009

AIR
(ALS)

Report To

Company

Contact:

Phone:

Street:

City/Province

Postal Code:

Invoice To

Company:

Contact:

Job #:

LSD:

PO / AFE:

ALS Sample #

(ALS use only)

18

3

125 -

Released by:

ALS Account # / Quote #

MOUNT

ALS Lab Work Order # (ALS use only):

Girls

COYF

CORE

Corc

Boys

Drinking Water (DW) Samples (client use)

Are samples taken from a Regulated DW System?

XX YES ☐ NO

TSF YES □ NO

Are samples for human consumption/ use?

www.alsglobal.com

Same as Report To

Copy of Invoice with Report

Vancouver School

Stephen Thomas

Vancouver B.C.

604 713-5637

1549 Clark Drive

Company address below will appear on the final report

Project Information

Placant

change

100

change

SHIPMENT RELEASE (client use)

Date:

100

200

Contact and company name below will appear on the final report

¥ YES □ NO

☐ YES ☐ NO

ELem entoru

Sample Identification and/or Coordinates

(This description will appear on the report)

127

126

218

MOON

room

RM

RM

RM

Canada Toll Free: 1 800 668 9878

7 EMAIL ☐ MAIL ☐ FAX

DY POF DEXCEL DEDD (DIGITAL)

☐ EMAIL ☐ MAIL ☐ FAX

Routing Code:

Time

(hh:mm)

17:56

12:58

12:59

03

Sample Type

water

water

water

water

water

Reports / Recipients

Invoice Recipients

Oil and Gas Required Fields (client use)

ALS Contact: T. Tarannum | Sampler: R. Leman

Date

(dd-mmm-yy)

19-Dez-22

19- Dec-22

19-186-22

19-186-22

19-DEC-22

Notes / Specify Limits for result evaluation by selecting from drop-down below

(Excel COC only)

PO#

Merge QC/QCI Reports with COA ☐ YES ☐ NO ☐ N/A

Compare Results to Criteria on Report - provide details below if box checked

Email 1 or Fax 65 thomas @ usb. br. ca.

Email 2 carrell @ usb. bc. ca

Email 3 idvong @ USB. bc.ca

Select Report Format:

Select Distribution:

Select Invoice Distribution:

Email 1 or Fax

AFE/Cost Center:

Major/Minor Code:

Requisitioner:

Location:

DE -

Bothle Filler

550F

DF

NF

123

Email 2

Page **Environmental Division** Turnaround Time (TAT) Requested Vancouver Routine [R] if received by 3pm M-F - no surcharges apply Work Order Reference 4 day [P4] If received by 3pm M-F- 20% rush surcharge minimum. VA22D0685 3 day [P3] If received by 3pm M-F - 25% rush surcharge minimum 2 day [P2] if received by 3pm M-F - 50% rush surcharge minimum 1 day [E] If received by 3pm M-F - 100% rush surcharge minimum Same day [E2] if received by 10am M-S - 200% rush surcharge, Additional may apply to rush requests on weekends, statutory holidays and non-routine Date and Time Required for all E&P TATs: For all tests with rush TATs requested, please contact Analysis Reques Telephone: +1 604 253 4188 CONTAINERS Indicate Filtered (F), Preserved (P) or Filtered and Pre EXTENDED STORAGE REQU SUSPECTED HAZARD (see HOLD S Р SAMPLES NUMBER SAMPLE RECEIPT DETAILS (ALS use only) Cooling Method: NONE TO NONE COOLING INITIATED Submission Comments identified on Sample Receipt Notification: YES Cooler Custody Seals Intact: Seals Intact: Sample Custody Seals Intact: INITIAL COOLER TEMPERATURES C INITIAL SHIPMENT RECEPTION (ALS use only) FINAL SHIPMENT RECEPTION (ALS use only)

REFER TO BACK PAGE FOR ALS LOCATIONS AND SAMPLING INFORMATION elithis form may delay easilysis. Please fill in this form LEGIBLY. By the use of this form the user acknowledges and agrees with the Terms and Conditions as specified on the back page of the white - report copy If any water samples are taken from a Regulated Drinking Water (DW) System, please submit using an Authorized DW COC form.

. No preservatives added

Results Summary VA22D0685

Project Mount Pleasant Elementary

Report To Stephen Thomas, Vancouver School Board

 Date Received
 19-Dec-2022 15:30

 Issue Date
 28-Dec-2022 16:34

Amendment 0

Client Sample ID			Giris Change room 133 DF	Corr 100 RM 127 DF	Bottle Filter	DF	SSDF
Date Sampled			19-Dec-2022	19-Dec-2022	19-Dec-2022	19-Dec-2022	19-Dec-2022
Time Sampled			12:56	12:58	12:59	13:03	13:07
ALS Sample ID			VA22D0685-001	VA22D0685-002	VA22D0685-003	VA22D0685-004	VA22D0685-005
Analyte	Lowest Detection Limit	Units	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water
Total Metals (Matrix: Water)							
lead, total	0.000050	mg/L	0.000899	0.000682	0.000066	0.00550	0.00174