ALS Canada Ltd.



CERTIFICATE OF ANALYSIS (GUIDELINE EVALUATION)

: VA23A1537 **Work Order** Page : 1 of 3

Client Laboratory : Vancouver - Environmental : Vancouver School Board

Contact : Stephen Thomas **Account Manager** : Tasnia Tarannum Address

: 1549 Clark Drive Address : 8081 Lougheed Highway

Vancouver BC Canada V5L 3L4 Burnaby, British Columbia Canada V5A 1W9

Telephone : ----Telephone : +1 604 253 4188 Project : Lord Selkirk Elementary **Date Samples Received** : 23-Jan-2023 15:00

Date Analysis Commenced : 25-Jan-2023 PO

: 25-Jan-2023 20:11 C-O-C number : 20-1038772 Issue Date Sampler : K. Messamore

Site

Quote number : Standing Offer

No. of samples received : 8 No. of samples analysed : 8

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results
- Guideline Comparison

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories Position Laboratory Department

Kim Jensen Department Manager - Metals Metals, Burnaby, British Columbia Page : 2 of 3 Work Order : VA23A1537

Client : Vancouver School Board
Project : Lord Selkirk Elementary



No Breaches Found

General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information. Guidelines are not adjusted for the hardness, pH or temperature of the sample (the most conservative values are used). Measurement uncertainty is not applied to test results prior to comparison with specified criteria values.

Key: LOR: Limit of Reporting (detection limit).

Unit	Description
mg/L	milligrams per litre

>: greater than.

Red shading is applied where the result is greater than the Guideline Upper Limit or the result is lower than the Guideline Lower Limit.

For drinking water samples, Red shading is applied where the result for E.coli, fecal or total coliforms is greater than or equal to the Guideline Upper Limit.

<: less than.

Page : 3 of 3 Work Order : VA23A1537

Client : Vancouver School Board
Project : Lord Selkirk Elementary



Analytical Results Evaluation

Matrix:	Clier	nt sample ID		 		 	
	Samplii	ng date/time		 		 	
		Sub-Matrix				 	
Analyte	CAS Number	Unit		 		 	
		-					
Please refer to the General Comments section for	or an explanation of any q	ualifiers dete	cted.		_		
Lead, total	7	7439-92-1	mg/L				



QUALITY CONTROL INTERPRETIVE REPORT

Work Order : **VA23A1537** Page : 1 of 6

Client : Vancouver School Board Laboratory : Vancouver - Environmental

Contact : Stephen Thomas Account Manager : Tasnia Tarannum

Address :1549 Clark Drive Address :8081 Lougheed Highway

Vancouver BC Canada V5L 3L4

Burnaby, British Columbia Canada V5A 1W9

Telephone :--- Telephone :+1 604 253 4188

Project : Lord Selkirk Elementary : 23-Jan-2023 15:00

PO : ---- Issue Date : 25-Jan-2023 20:11

Sampler : K. Messamore

· 20-1038772

Site :----

Quote number : Standing Offer

No. of samples received :8
No. of samples analysed :8

This report is automatically generated by the ALS LIMS (Laboratory Information Management System) through evaluation of Quality Control (QC) results and other QA parameters associated with this submission, and is intended to facilitate rapid data validation by auditors or reviewers. The report highlights any exceptions and outliers to ALS Data Quality Objectives, provides holding time details and exceptions, summarizes QC sample frequencies, and lists applicable methodology references and summaries.

Key

C-O-C number

Anonymous: Refers to samples which are not part of this work order, but which formed part of the QC process lot.

CAS Number: Chemical Abstracts Service number is a unique identifier assigned to discrete substances.

DQO: Data Quality Objective.

LOR: Limit of Reporting (detection limit).

RPD: Relative Percent Difference.

Workorder Comments

Holding times are displayed as "---" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Summary of Outliers

Outliers : Quality Control Samples

- No Method Blank value outliers occur.
- No Duplicate outliers occur.
- No Laboratory Control Sample (LCS) outliers occur
- No Matrix Spike outliers occur.
- No Test sample Surrogate recovery outliers exist.

Outliers: Reference Material (RM) Samples

No Reference Material (RM) Sample outliers occur.

Outliers: Analysis Holding Time Compliance (Breaches) ■ No Analysis Holding Time Outliers exist.

Outliers: Frequency of Quality Control Samples • No Quality Control Sample Frequency Outliers occur.

Page : 3 of 6 Work Order : VA23A1537

Client : Vancouver School Board
Project : Lord Selkirk Elementary



Analysis Holding Time Compliance

This report summarizes extraction / preparation and analysis times and compares each with ALS recommended holding times, which are selected to meet known provincial and/or federal requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by organizations such as CCME, US EPA, APHA Standard Methods, ASTM, or Environment Canada (where available). Dates and holding times reported below represent the first dates of extraction or analysis. If subsequent tests or dilutions exceeded holding times, qualifiers are added (refer to COA).

If samples are identified below as having been analyzed or extracted outside of recommended holding times, measurement uncertainties may be increased, and this should be taken into consideration when interpreting results.

Where actual sampling date is not provided on the chain of custody, the date of receipt with time at 00:00 is used for calculation purposes.

Where only the sample date without time is provided on the chain of custody, the sampling date at 00:00 is used for calculation purposes.

Evaluation: **x** = Holding time exceedance; ✓ = Within Holding Time Matrix: Water Analyte Group Sampling Date Extraction / Preparation Analysis Method Container / Client Sample ID(s) **Holding Times** Eval Analysis Date Holding Times Eval Preparation Rec Actual Rec Actual Date Total Metals: Total metals in Water by CRC ICPMS HDPE - total (lab preserved) E420 ✓ Basement 005 RM 022 SSDF 23-Jan-2023 25-Jan-2023 25-Jan-2023 180 2 days days Total Metals : Total metals in Water by CRC ICPMS HDPE - total (lab preserved) Boys Change RM 022 DF E420 23-Jan-2023 25-Jan-2023 25-Jan-2023 2 days ----180 days Total Metals: Total metals in Water by CRC ICPMS HDPE - total (lab preserved) E420 23-Jan-2023 ✓ Corr 100 RM 110 Bottle Filler 25-Jan-2023 25-Jan-2023 2 days 180 days Total Metals: Total metals in Water by CRC ICPMS HDPE - total (lab preserved) Corr 217 RM 214 Bottle Filler E420 23-Jan-2023 25-Jan-2023 25-Jan-2023 180 2 davs days Total Metals: Total metals in Water by CRC ICPMS HDPE - total (lab preserved) PLAY AREA 005 Bottle Filler E420 23-Jan-2023 25-Jan-2023 25-Jan-2023 2 days 1 180 days Total Metals: Total metals in Water by CRC ICPMS HDPE - total (lab preserved) E420 23-Jan-2023 25-Jan-2023 25-Jan-2023 ✓ RM 102 Building 109C DF 2 days 180 ---davs Total Metals : Total metals in Water by CRC ICPMS HDPE - total (lab preserved) Stair 199 Bottle Filler E420 23-Jan-2023 25-Jan-2023 25-Jan-2023 ✓ 2 days 180 days

Page : 4 of 6 Work Order : VA23A1537

Client : Vancouver School Board
Project : Lord Selkirk Elementary



Matrix: Water Evaluation: × = Holding time exceedance; ✓ = Within Holding Time

Evaluation: W = Holding time exceedance; V = Within Holding Time										
Analyte Group	Method	Sampling Date	Ext	raction / Pr	eparation			Analys		
Container / Client Sample ID(s)			Preparation	Holding Times Eval		Analysis Date	e Holding Times		Eval	
			Date	Rec	Actual			Rec	Actual	
Total Metals : Total metals in Water by CRC ICPMS										
HDPE - total (lab preserved) Stair 299 SSDF	E420	23-Jan-2023	25-Jan-2023				25-Jan-2023	180 days	2 days	✓

Legend & Qualifier Definitions

Rec. HT: ALS recommended hold time (see units).

Page : 5 of 6 Work Order : VA23A1537

Client : Vancouver School Board
Project : Lord Selkirk Elementary



Quality Control Parameter Frequency Compliance

The following report summarizes the frequency of laboratory QC samples analyzed within the analytical batches (QC lots) in which the submitted samples were processed. The actual frequency should be greater than or equal to the expected frequency.

Matrix: Water	Evaluation: × = QC frequency outside specification; ✓ = QC frequency within specification.											
Quality Control Sample Type		Co	ount	Frequency (%)								
Analytical Methods	Method	QC Lot #	QC	Regular	Actual	Expected	Evaluation					
Laboratory Duplicates (DUP)												
Total metals in Water by CRC ICPMS	E420	812521	1	16	6.2	5.0	✓					
Laboratory Control Samples (LCS)												
Total metals in Water by CRC ICPMS	E420	812521	1	16	6.2	5.0	✓					
Method Blanks (MB)												
Total metals in Water by CRC ICPMS	E420	812521	1	16	6.2	5.0	✓					
Matrix Spikes (MS)												
Total metals in Water by CRC ICPMS	E420	812521	1	16	6.2	5.0	✓					

Page : 6 of 6 Work Order : VA23A1537

Client : Vancouver School Board Project : Lord Selkirk Elementary



Methodology References and Summaries

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Reference methods may incorporate modifications to improve performance (indicated by "mod").

Analytical Methods	Method / Lab	Matrix	Method Reference	Method Descriptions
Total metals in Water by CRC ICPMS	E420	Water	EPA 200.2/6020B	Water samples are digested with nitric and hydrochloric acids, and analyzed by
			(mod)	Collision/Reaction Cell ICPMS.
	Vancouver -			
	Environmental			Method Limitation (re: Sulfur): Sulfide and volatile sulfur species may not be recovered
				by this method.

ALS Canada Ltd.



QUALITY CONTROL REPORT

Work Order :VA23A1537

Client : Vancouver School Board

: Stephen Thomas Contact Address

: 1549 Clark Drive

Vancouver BC Canada V5L 3L4

Telephone

Project : Lord Selkirk Elementary

PO :----

C-O-C number : 20-1038772 Sampler : K. Messamore

Site

Quote number : Standing Offer

No. of samples received : 8 No. of samples analysed 8 Page : 1 of 3

Laboratory : Vancouver - Environmental

Account Manager : Tasnia Tarannum

Address :8081 Lougheed Highway

Burnaby, British Columbia Canada V5A 1W9

Telephone :+1 604 253 4188

Date Samples Received : 23-Jan-2023 15:00

Date Analysis Commenced : 25-Jan-2023

Issue Date :25-Jan-2023 20:11

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Quality Control Report contains the following information:

Laboratory Duplicate (DUP) Report; Relative Percent Difference (RPD) and Data Quality Objectives

- Matrix Spike (MS) Report; Recovery and Data Quality Objectives
- Method Blank (MB) Report; Recovery and Data Quality Objectives
- Laboratory Control Sample (LCS) Report; Recovery and Data Quality Objectives

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories **Position** Laboratory Department

Kim Jensen Department Manager - Metals Vancouver Metals, Burnaby, British Columbia Page : 2 of 3 Work Order : VA23A1537

Client : Vancouver School Board
Project : Lord Selkirk Elementary



General Comments

The ALS Quality Control (QC) report is optionally provided to ALS clients upon request. ALS test methods include comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against predetermined Data Quality Objectives (DQOs) to provide confidence in the accuracy of associated test results. This report contains detailed results for all QC results applicable to this sample submission. Please refer to the ALS Quality Control Interpretation report (QCI) for applicable method references and methodology summaries.

Key:

Anonymous = Refers to samples which are not part of this work order, but which formed part of the QC process lot.

CAS Number = Chemical Abstracts Service number is a unique identifier assigned to discrete substances.

DQO = Data Quality Objective.

LOR = Limit of Reporting (detection limit).

RPD = Relative Percent Difference

= Indicates a QC result that did not meet the ALS DQO.

Workorder Comments

Holding times are displayed as "---" if no guidance exists from CCME, Canadian provinces, or broadly recognized international references.

Laboratory Duplicate (DUP) Report

A Laboratory Duplicate (DUP) is a randomly selected intralaboratory replicate sample. Laboratory Duplicates provide information regarding method precision and sample heterogeneity. ALS DQOs for Laboratory Duplicates are expressed as test-specific limits for Relative Percent Difference (RPD), or as an absolute difference limit of 2 times the LOR for low concentration duplicates within ~ 4-10 times the LOR (cut-off is test-specific).

Sub-Matrix: Water	Sub-Matrix: Water						Laboratory Duplicate (DUP) Report							
Laboratory sample ID	Client sample ID	LOR	Unit	Original Result	Duplicate Result	RPD(%) or Difference	Duplicate Limits	Qualifier						
Total Metals (QC Lo	t: 812521)													
KS2300221-001	Anonymous	Lead, total	7439-92-1	E420	0.000500	mg/L	<0.000500	<0.000500	0	Diff <2x LOR				

Method Blank (MB) Report

A Method Blank is an analyte-free matrix that undergoes sample processing identical to that carried out for test samples. Method Blank results are used to monitor and control for potential contamination from the laboratory environment and reagents. For most tests, the DQO for Method Blanks is for the result to be < LOR.

Sub-Matrix: Water

Analyte	CAS Number	Method	LOR	Unit	Result	Qualifier
Total Metals (QCLot: 812521)						
Lead, total	7439-92-1	E420	0.00005	mg/L	<0.000050	

Page : 3 of 3 Work Order : VA23A1537

Client : Vancouver School Board
Project : Lord Selkirk Elementary



Laboratory Control Sample (LCS) Report

A Laboratory Control Sample (LCS) is an analyte-free matrix that has been fortified (spiked) with test analytes at known concentration and processed in an identical manner to test samples. LCS results are expressed as percent recovery, and are used to monitor and control test method accuracy and precision, independent of test sample matrix.

Sub-Matrix: Water		Laboratory Control Sample (LCS) Report							
	Spike	Recovery (%)	Recovery	Limits (%)					
Analyte	CAS Number	Method	LOR	Unit	Concentration	LCS	Low	High	Qualifier
Total Metals (QCLot: 812521)									
Lead, total	7439-92-1	E420	0.00005	mg/L	0.5 mg/L	102	80.0	120	

Matrix Spike (MS) Report

A Matrix Spike (MS) is a randomly selected intra-laboratory replicate sample that has been fortified (spiked) with test analytes at known concentration, and processed in an identical manner to test samples. Matrix Spikes provide information regarding analyte recovery and potential matrix effects. MS DQO exceedances due to sample matrix may sometimes be unavoidable; in such cases, test results for the associated sample (or similar samples) may be subject to bias. ND – Recovery not determined, background level >= 1x spike level.

Sub-Matrix: Water			Matrix Spike (MS) Report								
						ke	Recovery (%)	Recovery			
Laboratory sample	Client sample ID	Analyte	CAS Number	Method	Concentration	Target	MS	Low	High	Qualifier	
ID				<u>'</u>							
Total Metals (QC	Lot: 812521)										
KS2300224-001	Anonymous	Lead, total	7439-92-1	E420	0.0192 mg/L	0.02 mg/L	96.0	70.0	130		

Chain of Custody (COC) / Analytical Request Form



www.alsglobal.com

Canada Toll Free: 1 800 668 9878

coc Number: 20 - 1038772

Page

of

Report To	Contact and company name below will appear	on the final report	Reports / Recipients						Turnaro	und Time (1	AT) Requ	ested		, S.	2.70	900		lab y	Self-
Company:	VANCOUVER SCHOOL	OL BOARD	Select Report Fo		□ excal □ E	DD (DIGITAL)	ΓΣ⊅ Ro	utine [R] if		3pm M-F - 4				101×	Q.Á.				
Contact:	STEPHEN THOM		Merge QC/QC	Reports with COA	_		17			3pm M-F- 2			imum	1,662	A STATE OF	Sec.			an ar Alas
Phone:	604 - 713 -563		Compare Resu	its to Criteria on Report - p	rovide details below if	box checked	3 day [P3] if received by 3pm M-F - 25% rush surcharge minimum						A	FFIX ALS	BARCOE (ALS use	ELABI	EL HER	tE 🎆	
	Company address below will appear on the final re	eport	Select Distribution	on: 🗗 EMAIL	☐ MAJL ☐	FAX							(ALS USE	only) 🍣	Ψ,	Million.			
Street:	1549 Clark a	Acive	Email 1 or Fax SSTHOMAS & VSB, BC, KA					☐ 1 day [E] if received by 3pm M-F - 100% rush surcharge minimum ☐ Same day [E2] if received by 10am M-S - 200% rush surcharge. Additional fees						ees			À.	Ē.	1
City/Province:	VANCOUVER BC	•	Email 2	CCarrell			may apply to rush requests on weekends, statutory holidays and non-routine tests							100 and	7		Bine id		
Postal Code:			Email 3	. Jduana (9 VSB. E	X.(A	Date and Time Required for all E&P TATs: dd-mmm-yy hh:mm an							:mm-am/	om.				
Invoice To	Same as Report To 12 YES □	NO		Invoice Re	cipients				Fo	r all tests with	rush TATs r	equested, pl	ase contact	your AM to	confirm ava	ilability.			
	Copy of Invoice with Report	NO	Select Invoice D	istribution: 🔲 🖽	AIL MAIL] FAX						Analysi	Reques	it				•	
Company:			Email 1 or Fax		1		S		Indicat	e Filtered (F),	Preserved	(P) or Filter	ed and Pres	served (F/P	below	•		ED	<u>§</u>
Contact:			Email 2				AINER							``]]	REQUIRED	HAZARD (see notes)
<u> </u>	Project Information		•	Oil and Gas Required	Fields (client u	50)] ⋛											<u>ii</u>	8
ALS Account # /			AFE/Cost Center:		PO#		5						•				ובו		S.
Job#: L	-ORD SELKIRK ELE	MENTARY	Major/Minor Code:		Routing Code:		CONT									1	HOLD	STORAGE	\ <u>\\</u>
PO / AFE:	•		Requisitioner:					1			1 .		1			- ∤.	8	용	31
LSD:	•		Location:	*	<u> </u>	-	8	\hat{A}						-		• .		ST	黃ㅣ
ALS Lab Worl	COrder # (ALS use only):	37	ALS Contact:	T. Toronum	Sampler: K, ∫v	ressomere	NUMBER				Envi	ronme	ntal E	Divisio	n - 1		SAMPLES	EXTENDED	SUSPECTED
ALS Sample #	Sample Identification a	and/or Coordinates		Date Time						-	Vano	ouver			"		₹	Œ	요
(ALS use only)	(This description will ap			(dd-mmm-yy)	(hh:mm)	Sample Type	ΙŽ			_	Wo	rk Orde	er Refe	rence	<u>Ł</u>		Ŝ	ũ	ಶ
	RM 102 Building	, 109C "D	F	23-JAN-23	9:30	WATER		, l	-		V	A2:	3A 1	53	7				
***************************************	STAIR 199 BOY	Ale Filler		23-JAN-23	9:34	WATER				7					' [\Box		1 -
100		SOF		23-JAN-23	9:36	WATER							80. 8 0	1 11 11	ı				
			SDF	23-1AN-23	9:40	WATER													
	Carr 100 RM	110 Bottle		23-1AN-23		WATER		- T		1						-			
	······································	MOZZ DE		23- JAN-23		WATER				7		1.5.	$Y_{i}(Y)$				\vdash		
	PLAY AREA 005		ler	23- JAN-23		WATER					Tolonia es				' 		\vdash		\dashv
78.14 (886)		214 Battle	Filler	23 - JAN -23		WATER		_		-{	- etoh lorn	e: +160	4 253 418	8	t		H		\dashv
**************************************	Car. 211 271 1	CII DOMIN	Falls	172 - 27410-02	10,00	VVITER	 						7 — - ₁		/		\vdash	\vdash	\dashv
38 5 1 1 1999;								_	-		\vdash		-		-		4		
<u>* * * * * * * * * * * * * * * * * * * </u>	•		<u> </u>									_	\sqcup				$oxed{oxed}$		
. The state of																			
Drinking	g Water (DW) Samples ¹ (client use)	Notes / Specif		evaluation by selecting	g from drop-down	below		ng Metho		SAI NONE								(TED	
	from a Regulated DW System?									dentified o						is 🌺 [MA.	arit.
. ® YE	s □ NO	Μ	Dro 60	cruatives	add	ړه				tact:								s 🗖	N/A
Are samples for hi	uman consumption/ use?	No.	1,000		Mau	LM	AMA(SE)			R TEMPERA		icalia.	** 1830	≨ FINAL	COOLER	TEMPERAT	URES *C	380e44	38.
₩ YE	S 🔲 NO	<u> </u>					. destan		tail.		166.		Branch Con	}			ing the	*	學
	SHIPMENT RELEASE (client use)		*** *********************************	INITIAL SHIPMENT					*******		FINAL	SHIPMEN	T RECEI	TION (A	LS use o	only) 🙈	4100.0	TWEET.	
Released by:	Date:	Time:			Date:	n de de Estables Residentes			eceived b		W con	Day	FAA1	12/1	رب السائد (ا	TAPONT.	Time	100) £ 00
REFER TO BACK R	L PAGE FOR ALS LOCATIONS AND SAMPLING INFO	RMATION	a de la companya de	WHI	TE - LABORATORY	COPY VELLO	N - CLIE	NT COPY	/ <u> </u>			š 39 2	アドン家	11/1		7100	1.12	minute and	30 D20 FRONT
	Strains 2007, Old Mile Origin Edite IIII C			44111	. C - CABONATORI	JOI I LELLON	,,		•					•					

Results Summary VA23A1537

Project Lord Selkirk Elementary

Report To Stephen Thomas, Vancouver School Board

 Date Received
 23-Jan-2023 15:00

 Issue Date
 25-Jan-2023 20:11

Amendment 0

Client Sample ID			RM 102 Building 109C DF	Stair 199 Bottle Filler	Stair 299 SSDF	Basement 005 RM 022 SSDF	Corr 100 RM 110 Bottle Filler	Boys Change RM 022 DF	PLAY AREA 005 Bottle Filler	Corr 217 RM 214 Bottle Filler
Date Sampled			23-Jan-2023	23-Jan-2023	23-Jan-2023	23-Jan-2023	23-Jan-2023	23-Jan-2023	23-Jan-2023	23-Jan-2023
Time Sampled			09:30	09:34	09:36	09:40	09:44	09:50	09:52	10:00
ALS Sample ID			VA23A1537-001	VA23A1537-002	VA23A1537-003	VA23A1537-004	VA23A1537-005	VA23A1537-006	VA23A1537-007	VA23A1537-008
Analyte	Lowest Detection Limit	Units	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water
Total Metals (Matrix: Water)										
Lead, total	0.000050	mg/L	0.00532	0.000119	0.000192	0.000173	0.000462	0.00144	0.000084	0.000121