



Date: 15-OCT-19

PO No.: 1517879

WO No.: L2361078

LSD:

Project Ref: TEMPLETON SECONDARY

Sample ID: CORR 318 RM. 317 DF

Sampled By: Robin Lemay


Date Collected: 07-OCT-19

Lab Sample ID: L2361078-1

Matrix: Water

VANCOUVER SCHOOL BOARD
Maintenance and Construction
 1549 Clark Drive
 Vancouver BC V5L 3L4
 ATTN: Stephen Thomas

PAGE 1 of 14

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.00107		mg/L	0.005		09-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						

ADDRESS: 8081 Lougheed Hwy, Suite 100, Burnaby, BC V5A 1W9 Canada | Phone: +1 604 253 4188 | Fax: +1 604 253 6700

ALS CANADA LTD Part of the ALS Group A Campbell Brothers Limited Company



Date: 15-OCT-19

PO No.: 1517879

WO No.: L2361078

LSD:

Project Ref: TEMPLETON SECONDARY

Sample ID: CORR 300 RM. 314 DF


Sampled By: Robin Lemay

Date Collected: 07-OCT-19

Lab Sample ID: L2361078-2

Matrix: Water

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.00108		mg/L	0.005		09-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 15-OCT-19

PO No.: 1517879

WO No.: L2361078

LSD:

Project Ref: TEMPLETON SECONDARY

Sample ID: CORR 200 RM. 213 DF


Sampled By: Robin Lemay

Date Collected: 07-OCT-19

Lab Sample ID: L2361078-3

Matrix: Water

VANCOUVER SCHOOL BOARD
Maintenance and Construction
 1549 Clark Drive
 Vancouver BC V5L 3L4
 ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.00241		mg/L	0.005		09-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 15-OCT-19

PO No.: 1517879

WO No.: L2361078

LSD:

Project Ref: TEMPLETON SECONDARY

Sample ID: CORR 230 RM. 223 DF


Sampled By: Robin Lemay

Date Collected: 07-OCT-19

Lab Sample ID: L2361078-4

Matrix: Water

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.00161		mg/L	0.005		09-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 15-OCT-19

PO No.: 1517879

WO No.: L2361078

LSD:

Project Ref: TEMPLETON SECONDARY

Sample ID: CORR 133 RM. 136 DF


Sampled By: Robin Lemay

Date Collected: 07-OCT-19

Lab Sample ID: L2361078-5

Matrix: Water

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.00193		mg/L	0.005		09-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 15-OCT-19

PO No.: 1517879

WO No.: L2361078

LSD:

Project Ref: TEMPLETON SECONDARY

Sample ID: RM. 120 BUB


Sampled By: Robin Lemay

Date Collected: 07-OCT-19

Lab Sample ID: L2361078-6

Matrix: Water

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.00301		mg/L	0.005		09-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 15-OCT-19

PO No.: 1517879

WO No.: L2361078

LSD:

Project Ref: TEMPLETON SECONDARY

Sample ID: CORR 173 RM. 185 FS


Sampled By: Robin Lemay

Date Collected: 07-OCT-19

Lab Sample ID: L2361078-7

Matrix: Water

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.00291		mg/L	0.005		09-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 15-OCT-19

PO No.: 1517879

WO No.: L2361078

LSD:

Project Ref: TEMPLETON SECONDARY

Sample ID: CORR 159 RM. 171 FS


Sampled By: Robin Lemay

Date Collected: 07-OCT-19

Lab Sample ID: L2361078-8

Matrix: Water

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.000388		mg/L	0.005		09-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 15-OCT-19

PO No.: 1517879

WO No.: L2361078

LSD:

Project Ref: TEMPLETON SECONDARY

Sample ID: RM. 163 DF


Sampled By: Robin Lemay

Date Collected: 07-OCT-19

Lab Sample ID: L2361078-9

Matrix: Water

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.00393		mg/L	0.005		09-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 15-OCT-19

PO No.: 1517879

WO No.: L2361078

LSD:

Project Ref: TEMPLETON SECONDARY

Sample ID: CORR 100 RM. 109 DF

Sampled By: Robin Lemay


Date Collected: 07-OCT-19

Lab Sample ID: L2361078-10

Matrix: Water

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

PAGE 10 of 14

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.00247		mg/L	0.005		09-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						

ADDRESS: 8081 Lougheed Hwy, Suite 100, Burnaby, BC V5A 1W9 Canada | Phone: +1 604 253 4188 | Fax: +1 604 253 6700

ALS CANADA LTD Part of the ALS Group A Campbell Brothers Limited Company



Date: 15-OCT-19

PO No.: 1517879

WO No.: L2361078

LSD:

Project Ref: TEMPLETON SECONDARY

Sample ID: RM. 129 BUB

Sampled By: Robin Lemay


Date Collected: 07-OCT-19

Lab Sample ID: L2361078-11

Matrix: Water

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

PAGE 11 of 14

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.00246		mg/L	0.005		09-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						

ADDRESS: 8081 Lougheed Hwy, Suite 100, Burnaby, BC V5A 1W9 Canada | Phone: +1 604 253 4188 | Fax: +1 604 253 6700

ALS CANADA LTD Part of the ALS Group A Campbell Brothers Limited Company



Date: 15-OCT-19

PO No.: 1517879

WO No.: L2361078

LSD:

Project Ref: TEMPLETON SECONDARY

Sample ID: RM. 125 BUB


Sampled By: Robin Lemay

Date Collected: 07-OCT-19

Lab Sample ID: L2361078-12

Matrix: Water

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.000904		mg/L	0.005		09-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 15-OCT-19

PO No.: 1517879

WO No.: L2361078

LSD:

Project Ref: TEMPLETON SECONDARY

Sample ID: RM. 127 BUB

Sampled By: Robin Lemay


Date Collected: 07-OCT-19

Lab Sample ID: L2361078-13

Matrix: Water

VANCOUVER SCHOOL BOARD
Maintenance and Construction
 1549 Clark Drive
 Vancouver BC V5L 3L4
 ATTN: Stephen Thomas

PAGE 13 of 14

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.000940		mg/L	0.005		09-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						

ADDRESS: 8081 Lougheed Hwy, Suite 100, Burnaby, BC V5A 1W9 Canada | Phone: +1 604 253 4188 | Fax: +1 604 253 6700

ALS CANADA LTD Part of the ALS Group A Campbell Brothers Limited Company

Guidelines & Objectives

Health Canada MAC Health Related Criteria Limits

Nitrate/Nitrite-N*	Criteria limit is 10 mg/L (1.0 mg/L if present as all Nitrite-N). High concentrations may contribute to blue baby syndrome in infants.
Lead*	A cumulative body poison, uncommon in naturally occurring hard waters.
Fluoride*	Present in fluoridated water supplies at 0.8 mg/L to reduce dental caries. Elevated levels causes fluorosis (mottling of teeth).
Total Coliforms*	Criteria is 0 CFU/100mL. Adverse health effects.
E. Coli*	Criteria is 0 CFU/100 mL. Certain E. Coli bacteria can be life threatening.
Manganese*	Criteria limit is 0.12 mg/L. Possible neurological effects in infants.

*Health Canada Canadian Drinking Water Quality Guidelines (MAC limit)

Aesthetic Objective Concentration Levels

Alkalinity	Acid neutralizing capacity. Usually a measure of carbonate and bicarbonates and calculated and reported as calcium carbonate.
Balance	Quality control parameter ratiating cations to anions
Bicarbonate	See Alkalinity. Report as the anion HCO ₃ -1
Carbonate	See Alkalinity. Reported at the anion CO ₃ -2
Calcium	See Hardness. Common major cation of water chemistry.
Chloride	Common major anion of water chemistry.
Conductance	Physical test measuring water salinity (dissolved ions or solids)
Hardness	Classical measure or capacity of water to precipitate soap (chiefly calcium and magnesium ions). Causes scaling tendency in water if carbonates/bicarbonates are present (if >200 mg/L). For drinking water purposes waters with results <200 mg/L are considered acceptable, results >200 mg/L are considered poor but can be tolerated. Results >500 mg/L are unacceptable.
Hydroxide	See alkalinity
Magnesium	See hardness. Common major cation of water chemistry. Elevated levels (>125 mg/L) may exert a cathartic or diuretic action.
pH	Measure of water acidity/alkalinity. Normal range is 7.0-8.5.
Potassium	Common major cation of water chemistry.
Sodium	Common major cation of water chemistry. Measure of salinity (saltiness).
Sulphate	Common major anion of water chemistry. Elevated levels may exert a cathartic or diuretic action.
Total Dissolved Solids	A measure of water salinity.
Iron	Causes staining to laundry and porcelain and astringent taste. Oxidizes to red-brown precipitate on exposure to air.
Heterotrophic	
Plate Count	Criteria is 500 cfu/mL Measure of heterotrophic bacteria present.

GLOSSARY OF REPORT TERMS

Surrogates are compounds that are similar in behaviour to target analyte(s), but that do not normally occur in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery. In reports that display the D.L. column, laboratory objectives for surrogates are listed there.

mg/kg - milligrams per kilogram based on dry weight of sample

mg/kg wwt - milligrams per kilogram based on wet weight of sample

mg/kg lwt - milligrams per kilogram based on lipid-adjusted weight

mg/L - unit of concentration based on volume, parts per million.

< - Less than.

D.L. - The reporting limit.

N/A - Result not available. Refer to qualifier code and definition for explanation.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Analytical results in unsigned test reports with the DRAFT watermark are subject to change, pending final QC review.



ALS Environmental

www.alslab.com

Canada Toll Free: 1 800 668 9878

Chain of Custody (COC) / Analytical Request Form

L2361078-COFC

COC Number: 17 - 756185

Page 1 of 2



Contact and company name below will appear on the final report

Report Format / Distribution

Select Service Level Below - Contact your A/M to confirm all E&P T&Ts (surcharges may apply)

Company: Vancouver School Board

Select Report Format: PDF EXCEL EDC (DIGITAL)

Regular (R) Standard T&T* if received by 3 pm - business days - no surcharges apply

Contact: Stephen Thomas

Quality Control (QC) Report with Report YES NO

1 Business day [E - 100%]

Phone: 604 713-5637

Select Distribution: EMAIL MAIL FAX

2 day [P2-50%]

Street: 1549 Clark Dr.

City/Province: Vancouver B.C.

Emergency: Same Day, Weekend or Statutory holiday [E2 -200%]
 Laboratory opening fees may apply []

Postal Code:

Invoice Distribution: EMAIL MAIL FAX

Date and Time Required for all E&P T&Ts: dd-mm-yy hh:mm

Invoice To: Same as Report To

Select Invoice Distribution: EMAIL MAIL FAX

Analysis Request

Company: Project Information

Oil and Gas Required Fields (client use)

Indicate Filtered (F), Preserved (P) or Filtered and Preserved (FP) below

ALS Account # / Quote #:

Job #: Templeton Secondary

PO / AFE: PO#

PO / AFE: Requisitioner:

ALS Contact: ALS Lab Work Order # (lab use only):

Routing Code:

LSD: Location:

Sampler: Robin Lemay

NUMBER OF CONTAINERS

Sample Identification and/or Coordinates

Date (dd-mm-yy)

Time (hh:mm)

Sample Type

Sample Type

SAMPLES ON HOLD

Corr 318 Rm. 317 DF

07-10-19 7:25am water

Lead

Corr 300 Rm. 314 DF

07-10-19 7:36am water

Corr 200 Rm. 213 DF

07-10-19 7:43am water

Corr 230 Rm. 223 DF

07-10-19 7:57am water

Corr 133 Rm. 136 DF

07-10-19 8:05am water

Rm. 120 Sub

07-10-19 8:14am water

Corr 173 Rm. 185 FS

07-10-19 8:23am water

Corr 159 Rm. 171 FS

07-10-19 8:31am water

Rm. 163 DF

07-10-19 8:39am water

Drinking Water (DW) Samples (client use)

Special Instructions / Specify Criteria to add on report by clicking on the drop-down list below (electronic COC only)

SAMPLE CONDITION AS RECEIVED (lab use only)

Are samples taken from a Regulated DW System? YES NO

No preservatives added

Frozen SIF Observations Yes No

Are samples for human consumption use? YES NO

Ice Packs Ice Cubes Custody seal intact Yes No

Cooling Initiated

SHIPPING RELEASE (client use)

INITIAL SHIPMENT RECEPTION (lab use only)

FINAL SHIPMENT RECEPTION (lab use only)

Released by: Date: Time: Received by: Date: Time:

Received by: Date: Time:

Received by: Date: Time:

REFER TO BACK PAGE FOR ALS LOCATIONS AND SAMPLING INFORMATION

WHITE - LABORATORY COPY YELLOW - CLIENT COPY

DATE OF REPORT

1. If any water samples are taken from a Regulated Drinking Water (DW) System, please submit using an Authorized DW COC form.

Final Date: 10/7

Final Date: 10/7

Final Time: 7:30p

Final Time: 7:30p

Final Time: 7:30p