



VANCOUVER SCHOOL BOARD  
ATTN: Facilities  
Maintenance and Construction  
1549 Clark Drive  
Vancouver BC V5L 3L4

Date Received: 12-MAY-16  
Report Date: 19-MAY-16 17:56 (MT)  
Version: FINAL

Client Phone: --

## Certificate of Analysis

**Lab Work Order #:** L1768363  
**Project P.O. #:** NOT SUBMITTED  
**Job Reference:**  
**C of C Numbers:** 14-497445, 14-497447, 14-497616  
**Legal Site Desc:**

**Comments:** Report separated by school.

Dean Watt, B.Sc.  
Account Manager

[This report shall not be reproduced except in full without the written authority of the Laboratory.]

ADDRESS: 8081 Lougheed Hwy, Suite 100, Burnaby, BC V5A 1W9 Canada | Phone: +1 604 253 4188 | Fax: +1 604 253 6700  
ALS CANADA LTD Part of the ALS Group A Campbell Brothers Limited Company

# ALS ENVIRONMENTAL ANALYTICAL REPORT

	<b>Sample ID</b> <b>Description</b> <b>Sampled Date</b> <b>Sampled Time</b> <b>Client ID</b>	L1768363-6 Water 12-MAY-16 11:50 UNIVERSITY HILL ELEM 109-DF	L1768363-7 Water 12-MAY-16 11:50 UNIVERSITY HILL ELEM 160-SINK	L1768363-8 Water 12-MAY-16 UNIVERSITY HILL ELEM 159-DF	
Grouping	Analyte				
<b>WATER</b>					
<b>Total Metals</b>	Lead (Pb)-Total (mg/L)	<0.000050	0.000932	<0.000050	