

Results Summary VA23C7816

Project Vancouver Technical Secondary
Report To Stephen Thomas, Vancouver School Board
Date Received 17-Nov-2023 14:40
Issue Date 23-Nov-2023 17:16
Amendment 0

Client Sample ID			Corr. 258 Rm. 207 Bottle Filler	Corr. 353 Rm. 317 Bottle Filler	Corr. 453 Rm. 411 Bottle Filler	Rm. C803 Bottle Filler	Rm. 616 SSDF	Rm. 602 Bubbler	Corr. 700 Rm. 700A Bottle Filler
Date Sampled			17-Nov-2023	17-Nov-2023	17-Nov-2023	17-Nov-2023	17-Nov-2023	17-Nov-2023	17-Nov-2023
Time Sampled			07:26	07:30	07:34	07:42	07:49	07:58	08:05
ALS Sample ID			VA23C7816-001	VA23C7816-002	VA23C7816-003	VA23C7816-004	VA23C7816-005	VA23C7816-006	VA23C7816-007
Analyte	Lowest Detection Limit	Units	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water	Sub-Matrix: Water
Total Metals (Matrix: Water)									
Lead, total	0.000050	mg/L	0.000479	0.000076	0.00182	0.000366	0.000280	0.000807	0.00221